# RESOLUTION NO. 20 - 54

## **Bonner County Jail**

## Budget Transfer from Salaries "A" to Current Expenses "B"

WHEREAS, Idaho Code 31-1605 provides that the Board of County Commissioners may adjust the budget as adopted, provided that there shall be no increase in anticipated property taxes; and,

WHEREAS, the Bonner County Jail has an overage in the "A" Budget 03478-6020 Salaries, and;

WHEREAS, this overage can be used to cover the unanticipated cost of a new Fire Alarm Control Panel and its installation.

NOW, THEREFORE, BE IT RESOLVED that the Board of Commissioners of Bonner County authorizes the Clerk to open the Jail "A" budget and transfer from 03478-6020 Salaries to the "B" budget and increase line item 03461 - 9420 Capital - Equipment by \$34,512.57.

ADOPTED as a Resolution of the Board of Commissioners of Bonner County upon a majority vote on the Alba day of July, 2020.

BOARD OF BONNER COUNTY COMMISSIONERS

Dan McDonald, Chairman

Jeff Connolly, Commissioner

Steven Bradshaw, Commissioner

ATTEST: Michael Rosedale

Deputy Clerk



# **Bonner County Sheriff's Office**

4001 N Boyer Road · Sandpoint, ID 83864 · Phone: (208) 263-8417

July 21, 2020

# Memorandum

To: **Board of County Commissioners** 

From: Sheriff Daryl Wheeler

Re: Resolution for Jail A to B Fund Transfer

The Jail is in need of a new fire suppression system. We have received three quotes the enclosed is the lowest in the amount of \$34,512.57. The Jail has an overage in the "A" budget, we are requesting to transfer \$34,512.57 from the "A" budget 03478-6020 Salaries to the "B" budget. And increase line item 03461-9420 Capital - Equipment. This will be used to cover the cost of the new fire suppression system.

`This Request and Resolution has been approved by:

Auditing - Mike Rosedale

A suggested motion would be: Mr. Chairman based on the information before us, I move to approve Resolution #20- 54 authorizing the Clerk to open the Jail "A" budget and transfer from 03478-6020 Salaries to the "B" budget and increase line item 03461-9420 -Capital - Equipment by \$34,512.57.

Recommendation Acceptance: yes one Commissioner Dan McDonald, Chairman

#### SCOPE OF WORK

This is an estimate to replace the existing Notifier AFP400 panel located at the Bonner County Jail (4001 N Boyer Ave) with a Silent Knight 5820 panel. Functionally this is a 1:1 replacement, meaning virtually every device of the old system will be replaced with the identical newer version of itself, no new devices/locations will be added, nor any old locations/devices removed (just replaced).

- Every input device that has a life cycle (smoke detectors, heat detectors, duct detectors, HVAC relays, contact inputs, and pull stations) will be replaced.
- Every proprietary device will also be replaced including all keypads, panels, or modules for the system.
- All pathways (conduit) and wiring will be re-used with the new system as it does not suffer from a life-cycle that normally requires replacement.
- Additionally all notification devices (sirens, speakers, strobes) will also not be replaced as they are compatible with both systems and do not suffer from a life-cycle that normally requires replacement.

#### DESCRIPTION OF WORK TO BE PERFORMED

Logistically the system replacement will be time consuming and difficult as we will avoid ever having a loss of coverage. The new system will be installed in the penthouse area above booking and will be running concurrently with the old system. This will include some work performed by an electrical subcontractor for power requirements (cost included in bid). My preferred vendor is Fogg Electric but I can also work with other if requested. Once this is in place, we'll slowly remove sections of the old devices and install them onto the new system until this process is complete, at which point the old panel in booking will be removed and replaced with a keypad so they still have access to the entire system. This will include a significant amount of labor including working around the Jail schedule for obtaining their assistance for work inside or around pods/inmates or even relocating inmates at times, all of this has be included in the estimate.

Finally, upon completion and approval by the AHJ (Selkirk Fire District) we will provide all system design schematics (current draw, voltage drop, device list, output matrix, and battery calcs), all codes, and a backup copy of the program and software on a USB key.

#### WARRANTY

As all devices to be used are Silent Knight (like multiple other county systems), I do honor their 36 month manufacturers warranty for all of their equipment. Additionally I have always stood behind my own work for its lifetime to be free from defect.

Thank you for the opportunity to provide this estimate and I look forward to working with you. If you have any questions please give me a call, thanks!

Note 1: This system should be monitored by an alarm company for all signals (the existing panel is not), this monitoring is an ongoing annual cost. The system will support this feature but that annual cost is not included in this estimate, that is a separate cost (typically ~\$300/annually).

Benjamin J. Curto

## Connect Technologies, Inc

PO Box 931 Sandpoint, ID 83864

# **Proposal**

Proposal Date: 4/30/2020 Proposal #: 20-039

Project: Bonner County Jail

Bill To:

Bonner County Jail 4001 N. Boyer Sandpoint, ID 83864

#### Description

### Est. Hours/Qty.

Silent Knight 6808 Addressable Fire Alarm Control Panel (198 Points)	. 1
Silent Knight 6815 Loop Expander	1
Silent Knight Remote Annunciator	4
Silent Knight Addressable Smoke/Heat Base Plate	133
Silent Knight Addressable Heat Detector	11
Silent Knight Addressable Photoelectric Smoke Detector	122
Silent Knight Addressable Dual Action Pull Station	12
Silent Knight Addressable Input Module	5
Silent Knight Addressable Relay Module	18
Service Call Labor	1
Programing/Technical Labor	1
Silent Knight Addressable Heat Detector	1
Spare Parts	
Silent Knight Addressable Photoelectric Smoke Detector	
Silent Knight Addressable Dual Action Pull Station	8
Silent Knight Addressable Smoke/Heat Base Plate	1
Silent Knight Addressable Heat Detector	6
Silent Knight Addressable Input Module	[ 2
Silent Knight Addressable Relay Module	1
One it is inglify tadded babble it to by foldable	3
Electrical Subcontractor for 120vac work	
Subcontracted Electrical for new panel	1
	1

Total

\$34,512.57

(0.0%)

\$0.00