



If we can't find you – we can't help you!

We need your help. There are an increasing number of homes that we cannot easily identify the address for. Please help us to locate your residence more easily in an emergency. Make sure to provide this same address to the 911 call taker in the event of an emergency.


- Post an address highly visible from the street
- We recommend at least 3" numbers on a contrasting background
- Ensure it is not blocked by shrubs or trees
- We would ask that you **do not** use black or dark numbers
- Please avoid cursive writing



If we can't get to you – we can't help you!

Residential driveways are critical for Fire and EMS access to your home and property. If you are building a new home, or making improvements to your property, please look at these recommendations from your local Fire District:

- To allow for access, driveways should be no steeper than a 10% grade
- An all-weather surface should be considered
- Year-round snow removal is highly recommended
- A minimum width of 12' and a height of 13.5' is required for a fire engine to access your driveway
- Driveways longer than 150' should provide a turnaround (top or bottom)
- Although not enforced in Bonner County, residential driveway requirements are found in the Idaho Administrative Code (IDAPA)



Bonner County Planning Department – Fire Sign Off

A copy of your proposed plans and plat map will be required at the time of Fire District review.

Applicant Name: _____

BLP#: _____

Parcel number (RP#): _____

Project Address: _____

Platted Lot: Yes No

Subdivision Name: _____

Block & Lot: _____

Fire District: _____

(Fire District use below)

Requirements: _____

Cistern/Storage Tank: Fire Suppression: Sprinkler System:

Other: _____

Approved: Yes No

Fire District Signature: _____ Date: _____

Comments:
