
Bonner County Planning - Agency Review - SS0005-21

Frederick, Adam <Adam.Frederick@idwr.idaho.gov>
To: Bonner County Planning <planning@bonnercountyid.gov>

Thu, Feb 10, 2022 at 12:57 PM

Bonner County Planning Department:

Thank you for providing the opportunity to comment on the proposed project. The Idaho Department of Water Resources (IDWR) takes no position on this proposal but recognizes that some activities will fall within its jurisdiction. Construction of a new well must comply with drilling permit requirements of Section 42-235, Idaho Code, and applicable Well Construction Rules. If the proposed well is intended to be used for domestic purposes as defined in Idaho Code § 42-111 (for a household, no more than 13,000 gallons per day including up to a ½ acre of irrigation), the use will not require approval from IDWR. If the well will be used to irrigate more than ½ acre, use more than 13,000 gallons per day, **or be shared by more than one household**, the owner will need to file for and receive approval of an *Application for Permit* before a well drilling permit can be approved.

The applicant can contact the Department with any questions.

Sincerely,

Adam



Adam Frederick | Water Rights Supervisor

Idaho Department of Water Resources

Northern Regional Office

7600 N Mineral Drive, Suite 100

Coeur d'Alene, ID 83815-7763

Phone: (208) 762-2800

From: Bonner County Planning <planning@bonnercountyid.gov>

Sent: Wednesday, February 2, 2022 10:00 AM

[Quoted text hidden]

[Quoted text hidden]

image001.png
31K



IDAHO DEPARTMENT OF
WATER RESOURCES