



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Notice of Public Hearing - File CUP0020-23 - Conditional Use Permit - Public Utility Facility

1 message

Kristie May <Kristie.May@deq.idaho.gov>

Wed, Mar 20, 2024 at 10:00 AM

To: Bonner County Planning Department <planning@bonnercountyid.gov>

Good Morning,

Thank you for the opportunity to provide comment. DEQ has the following comments for the project listed above.

The backup generator included in this project, if operated less than 225 hrs. per month, would meet Category II Exemption requirements for an air quality permit under IDAPA 50.01.01.222.c.iii. To maintain this exemption the facility must maintain records of hours of operation on a monthly basis.

For this CUP DEQ recommends that the county require the facility to maintain records of operation of the backup generator on a monthly basis. The records should be maintained for a minimum of two years and be made available to county or DEQ personnel when requested.

If you have any questions about the comments this project has received please contact the following at the number listed below:

- Katy Baker-Casile for engineering and wastewater.
- Anna Moody for drinking water.
- Shawn Sweetapple for air quality.
- Kevin Aardahl for remediation or RCRA.
- Robert Steed for surface water and setback requirements.

Thank you-

Idaho Department of Environmental Quality
2110 Ironwood Parkway, Coeur d'Alene, Idaho 83814
Office Line: 208.769.1422

www.deq.idaho.gov

Our mission: To protect human health and the quality of Idaho's air, land, and water.

From: Bonner County Planning Department <planning@bonnercountyid.gov>**Sent:** Tuesday, March 5, 2024 8:36 AM**To:** Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Assessors Office Group <assessorsgroup@bonnercountyid.gov>; Avista Copr - Jay West <jay.west@avistacorp.com>; Bay Drive Recreation District

<kirbymc45@gmail.com>; Bayview Water & Sewer <bwsd637@gmail.com>; BC Airport Manager Dave Schuck <dave.schuck@bonnercountyid.gov>; BC EMS Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Bonner Sheriff <bonnersheriff@bonnerso.org>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Kootenai - Ronda Whittaker <cityclerk@cityofkootenai.org>; City of Oldtown <cityofoldtown@hotmail.com>; City of Ponderay KayLeigh Miller <klmiller@ponderay.org>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint <cityplanning@sandpointidaho.gov>; <cityclerk@spiritleakeid.gov>; Coolin Sewer <coolinsewer@gmail.com>; Coolin-Cavanaugh Bay Fire District <coolinfirechief@gmail.com>; Kristie May <Kristie.May@deq.idaho.gov>; Drainage District #7 Kim Hoodenpyle <kjh5345@gmail.com>; East Bonner Library <vanessa@ebonnerlibrary.org>; East Priest Lake Fire Chief Tom Renzi <epbfdchief@gmail.com>; Ellisport Bay Sewer District <clerk@ebsewerdistrict.com>; Facilities Director LPOSD #84 <matt.diel@lposd.org>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Granite Reeder Sewer District <granitereeder@gmail.com>; Dan Everhart <Dan.Everhart@ishs.idaho.gov>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; IDL - Nav. Waters Ryan Zandhuisen <RZandhuisen@idl.idaho.gov>; IDL - Pend Oreille Lake Supervisory <esjoquist@idl.idaho.gov>; <dbrown@idl.idaho.gov>; Northern Info <northerninfo@idwr.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; ITD <D1Permits@itd.idaho.gov>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Kootenai Ponderay Sewer District <CJohnson@kootenaiponderaysewerdistrict.org>; Laclede Water District <LWdistrict@frontier.com>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lakeland Joint School District #272 Jessica Grantham <jessica.grantham@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; North of the Narrows Fire Dept <Huckbay2501@gmail.com>; Northern Lights - Kristin Mettke <kristin.mettke@nli.coop>; Northside Fire District - Karen Quenell <kquenell@northsidefire.org>; Outlet Bay Sewer District <outletbaysewer@gmail.com>; Pend Orielle Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHapplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Priest Lake Translator District - Frankie Dunn <Frankiejdunn@hotmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ruen Yeager <planning@ruenyeager.com>; Sagle Valley Water & Sewer District <saglewatersewer@gmail.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; <joekren@sd83.org>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; Schweitzer Fire, Spencer Newton <firedistrict@msn.com>; Selkirk Fire Gavin Gilcrease <ggilcrease@selkirkfire.com>; Selkirk Recreation District <elgar@whoi.edu>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Spirit Lake Fire Dept. (Debbie Carpenter) <chief@spiritleakefire.com>; Superintendent No. 84 Becky Meyer <becky.meyer@lposd.org>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Syringa Heights Water <allwater49@outlook.com>; Timberlake Fire <cthatcher@timberlakefire.com>; Trestle Creek Sewer District Janice Best <janicesb@televar.com>; US Fish & Wildlife Services - Christy Johnson Hughes <FW1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>; West Priest Lake Fire Josh Gilbert <WPLFD.Chief@gmail.com>

Cc: Robert Winningham <robertb.winningham@bonnercountyid.gov>; Travis Haller <travis.haller@bonnercountyid.gov>; Jacob Gabell <jake.gabell@bonnercountyid.gov>; <jennifer.halsing@intermountainif.com>; <david.kilburn@mtc.com>; Dave Yount <DYOUNT@spokaneproduce.com>

Subject: Notice of Public Hearing - File CUP0020-23 - Conditional Use Permit - Public Utility Facility

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

Jenna Crone, Hearing Coordinator

Bonner County Planning Department

208-265-1458 ext - 1277