

Scott Brown

From: Sam Owen Fire Rescue Sam Owen Fire Rescue <samowenfire@gmail.com>
Sent: Thursday, April 24, 2025 11:11 AM
To: Scott Brown
Subject: Re: Idaho Club Marina and Lakeshore Community

Hi Scott: In review of the drawings you have sent Sam Owen Fire District would be able to use the turn around area as drawn.

Please let me know if you have any questions or concerns.

Thank You
Tim Scofield
Sam Owen Fire District Chief
208-304-7822


On Tue, Apr 15, 2025 at 1:35 PM Scott Brown <sbrown@jasewell.com> wrote:

Tim,

I am creating road plans for the referenced development and would appreciate feedback from Sam Owen Fire regarding the proposed access to a future 30,000 sf building as shown on the attached plan. Three sides of the building can be accessed with fire apparatus within 150', which I think is ok (correct me if I am wrong). Is there enough room for your fire apparatus to turn around and the end of the road? The paved apron at the north end of the building is big enough to include a 50' diameter turnaround. If not, any suggestions?

Thank you, I appreciate your time.

B. Scott Brown, P.E.



1319 North Division Avenue

Sandpoint, Idaho 83864

Office: (208) 263-4160