



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Notice of Public Hearing - File MOD0006-24-Modification of Conditional Use Permit - Modification to Commercial Marina (C0925-09)

1 message

DEQ Comments <deqcomments@deq.idaho.gov>

Wed, Jan 8, 2025 at 12:31 PM

To: Bonner County Planning Department <planning@bonnercountyid.gov>

Per the application, the drinking water system serving this project would meet the definition of a public drinking water system (PWS) serving 25 people 60 days or more per year and must meet the requirements of a transient, non-community PWS under the Idaho Rules for Public Drinking Water Systems (Rules). If the CUP is approved the owner must meet the following requirements prior to developing and serving water to the public:

- The well location and construction must first be assessed and approved by DEQ. If it cannot be approved to meet Idaho Rules, another drinking water site and source must be approved.
- A facility plan and preliminary engineering report (PER) developed by an Idaho licensed professional engineer, which includes relevant requirements listed in IDAPA 58.01.18 Section 500, must be submitted to and approved by DEQ.
- Plans and specifications for the drinking water infrastructure to serve this project must be submitted to DEQ by an Idaho licensed professional engineer and approved by DEQ, and the well pump test must be performed and approved in accordance with DEQ requirements.
- Initial water quality monitoring must be performed.

Contact Katy Baker-Casile or Anna Moody at DEQ in Coeur d'Alene for further information (208) 769-1422.

If you have any questions about the comments this project has received please contact:

- Katy Baker-Casile for engineering and wastewater.
- Anna Moody for drinking water.
- Shawn Sweetapple for air quality.
- Kevin Aardahl for remediation or RCRA.
- Robert Steed for surface water and setback requirements.

Thank you-

Idaho Department of Environmental Quality
2110 Ironwood Parkway, Coeur d'Alene, Idaho 83814
Office Line: 208.769.1422

www.deq.idaho.gov

Our mission: To protect human health and the quality of Idaho's air, land, and water.

From: Bonner County Planning Department <planning@bonnercountyid.gov>

Sent: Thursday, November 21, 2024 9:00 AM

To: Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Assessors Office Group <assessorsgroup@>

bonnercountyid.gov>; Avista Copr - Jay West <jay.west@avistacorp.com>; Bay Drive Recreation District <kirbymc45@gmail.com>; Bayview Water & Sewer <bwsd637@gmail.com>; BC Airport Manager Dave Schuck <dave.schuck@bonnercountyid.gov>; BC EMS Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Bonner Sheriff <bonnersheriff@bonnerso.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Kootenai - Ronda Whittaker <cityclerk@cityofkootenai.org>; City of Oldtown <cityofoldtown@hotmail.com>; City of Ponderay KayLeigh Miller <klmiller@ponderay.org>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint <cityplanning@sandpointidaho.gov>; <cityclerk@spiritlakeid.gov>; Coolin Sewer <coolinsewer@gmail.com>; Coolin-Cavanaugh Bay Fire District <coolinfirechief@gmail.com>; DEQ Comments <deqcomments@deq.idaho.gov>; Drainage District #7 Kim Hoodenpyle <kjh5345@gmail.com>; East Bonner Library <vanessa@ebonnerlibrary.org>; East Priest Lake Fire Chief Tom Renzi <eplfdchief@gmail.com>; Ellisport Bay Sewer District <clerk@ebsewerdistrict.com>; Facilities Director LPOSD #84 <matt.diel@lposd.org>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Granite Reeder Sewer District <granitereeder@gmail.com>; Dan Everhart <Dan.Everhart@ishs.idaho.gov>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; Mike Ahmer <mahmer@idl.idaho.gov>; IDL - Nav. Waters Ryan Zandhuisen <RZandhuisen@idl.idaho.gov>; IDL - Pend Oreille Lake Supervisory <esjoquist@idl.idaho.gov>; <dbrown@idl.idaho.gov>; IDWR Chase Bell <chase.bell@idwr.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; ITD <D1Permits@itd.idaho.gov>; Jack Schenck Vyve/Northland Cable <Jack.schenck@vyvebb.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kootenai Ponderay Sewer District <CJohnson@kootenaiponderaysewerdistrict.org>; Laclede Water District <LWdistrict@frontier.com>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lakeland Joint School District #272 Jessica Grantham <jessica.grantham@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; North of the Narrows Fire Dept <Huckbay2501@gmail.com>; Northern Lights - Kristin Mettke <kristin.mettke@nli.coop>; Northside Fire District - Karen Quenell <kquenell@northsidefire.org>; Outlet Bay Sewer District <outletbaysewer@gmail.com>; Pend Orielle Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHApplications@phd1.idaho.gov>; Priest Lake Public Library District <plpliblibrary@hotmail.com>; Priest Lake Translator District - Frankie Dunn <Frankiejedunn@hotmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ruen Yeager <planning@ruenyeager.com>; Sagle Valley Water & Sewer District <saglewatersewer@gmail.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; <joekren@sd83.org>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; Schweitzer Fire, Spencer Newton <firedistrict@msn.com>; Selkirk Association of Realtors Danielle <danielle@selkirkraor.com>; Selkirk Fire Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Selkirk Recreation District <selgar@mac.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Spirit Lake Fire Dept. (Debbie Carpenter) <chief@spiritlakefire.com>; Superintendent No. 84 Becky Meyer <becky.meyer@lposd.org>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Syringa Heights Water <allwater49@outlook.com>; Timberlake Fire <kwright@timberlakefire.com>; Trestle Creek Sewer District Janice Best <janicesb@televar.com>; US Fish & Wildlife Services - Christy Johnson Hughes <FW1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>; West Priest Lake Fire Josh Gilbert <WPLFD.Chief@gmail.com>

Subject: Notice of Public Hearing - File MOD0006-24-Modification of Conditional Use Permit - Modification to Commercial Marina (C0925-09)

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

Jessica Montgomery, Hearing Coordinator

1/8/25, 12:41 PM

Bonner County Mail - [EXT SENDER] RE: Notice of Public Hearing - File MOD0006-24-Modification of Conditional Use Permit - Mo...

Bonner County Planning Department

(208) 265-1458 x1277