



Dylan Young <dylan.young@bonnercountyid.gov>

Bonner County Planning - File MOD0004-25 Agency Review

Bowman, Micki <Micki.Bowman@idwr.idaho.gov>
To: "planning@bonnercountyid.gov" <planning@bonnercountyid.gov>
Cc: "Bell, Chace" <Chace.Bell@idwr.idaho.gov>

Tue, Jul 15, 2025 at 11:52 AM

After review of application MOD0004-25, IDWR does not have any comments. Water use will be limited to quantities and volumes associated with water right 96-8787.

Thank you for the opportunity to comment,

Micki Bowman | Administrative Assistant 1

Idaho Department of Water Resources

Northern Regional Office

7600 N Mineral Drive, Suite 100

Coeur d'Alene, ID 83815-7763

Phone (208) 762-2807



From: Bonner County Planning Department <planning@bonnercountyid.gov>

Sent: Tuesday, July 1, 2025 8:54 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Carrol Stejer <CASTEJER@gmail.com>; Bell, Chace <Chace.Bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spiritlelakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Kootenai <cityclerk@cityofkootenai.org>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>;

cityclerk@spiritleakeid.gov <cityclerk@spiritleakeid.gov>; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; dbrown@idl.idaho.gov <dbrown@idl.idaho.gov>; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dave Schuck <dave.schuck@bonnercountyid.gov>; Dean Davis <deandavis@sd83.org>; Kristie May <Kristie.May@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejdunn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Dan Everhart <Dan.Everhart@ishs.idaho.gov>; DEQ Comments <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <robert.beachler@itd.idaho.gov>; ITD - Stacy Simkins <stacy.simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Jamie Brown <jamieb@inlandpower.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <jason.kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; joekren@sd83.org <joekren@sd83.org>; Jordan Brooks <coolinsewer@gmail.com>; Karen Quenell <kquenell@northsidefire.org>; KayLeigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Ken Flint <ken_flint@tcenergy.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lacedewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHApplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone.legg@itd.idaho.gov <Symone.legg@itd.idaho.gov>; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <eplfdchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>
Cc: Janna Brown <janna.brown@bonnercountyid.gov>; Jeannie Welter <jeannie.welter@bonnercountyid.gov>; Dylan Young <dylan.young@bonnercountyid.gov>
Subject: Bonner County Planning - File MOD0004-25 Agency Review

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

[Quoted text hidden]



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] Re: Bonner County Planning - File MOD0004-25 Agency Review

1 message

Symone Legg <Symone.Legg@itd.idaho.gov>

Tue, Jul 1, 2025 at 9:21 AM

To: Bonner County Planning Department <planning@bonnercountyid.gov>

Cc: Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>

This approach has been permitted for a commercial approach. Traffic volumes cannot exceed 300 cars on Sundays/church events unless a change-in-use permit has been approved. Permittee must comply with the provisions in the permit letter. Permit no. 1-25-436-A. ITD Permits has no objection.

Thank you,

Symone Legg | Project Coordinator**Idaho Transportation Department** | D1 Traffic/Permits

Ext: 208.772.8073 Dept: 208.772.1297

Email: symone.legg@itd.idaho.gov | itd.idaho.gov**Enhancing quality of life through transportation**

Work schedule: Monday – Thursday 6:00AM-4:30PM

From: Bonner County Planning Department <planning@bonnercountyid.gov>**Sent:** Tuesday, July 1, 2025 8:54 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Carrol Stejer <CASTEJER@gmail.com>; Chace Bell <chace.bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spiritleakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; Manda Corbett <cityclerk@cityofkootenai.org>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spiritleakeid.gov <cityclerk@spiritleakeid.gov>; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; Dan Brown <dbrown@idl.idaho.gov>; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dave Schuck <dave.schuck@bonnercountyid.gov>; Dean Davis <deandavis@sd83.org>; DEQ - Kristie McEnroe <kristie.mcenroe@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejduhn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; ID State Historical Society - Dan Everhart <dan.everhart@ishs.idaho.gov>; Idaho Department of Environmental Quality <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdcclerk@gmail.com>; Robert Beachler <Robert.Beachler@itd.idaho.gov>; Stacy Simkins <Stacy.Simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Jamie Brown <jamieb@inlandpower.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling

<Jason.Kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; Joe Kren <joekren@sd83.org>; Jordan Brooks <coolinsewer@gmail.com>; Karen Quenell <kquenell@northsidefire.org>; Kayleigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Ken Flint <ken_flint@tcenergy.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lacedewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Merritt Horsmon <merritt.horsmon@idfg.idaho.gov>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHApplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzanhuisen@idl.idaho.gov>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone Legg <Symone.Legg@itd.idaho.gov>; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <eplfdchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>

Cc: Janna Brown <janna.brown@bonnercountyid.gov>; Jeannie Welter <jeannie.welter@bonnercountyid.gov>; Dylan Young <dylan.young@bonnercountyid.gov>

Subject: Bonner County Planning - File MOD0004-25 Agency Review

CAUTION: This email originated outside the State of Idaho network. Verifv links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Very Respectfully,

Dylan Young
Hearing Coordinator

Bonner County Planning Department
1500 Highway 2, Suite 208
Sandpoint, ID 83864
Phone: 208-265-1458



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] House of the Lord denial

1 message

Wpfd District 1 <wpofd1@gmail.com>

Tue, Jul 15, 2025 at 9:44 AM

To: planning@bonnercountyid.gov

Letter from State Fire Marshal's office and denial from WPOFD.
MOD0004-25.
Chief Jamie Painton WPOFD

2 attachments**HOUSE OF THE LORD DENIAL.PDF**

285K

**House of the Lord fire sign off.PDF**

519K



1500 Highway 2, Suite 208, Sandpoint, Idaho 83864

Phone (208) 265-1458 - Fax (866) 537-4935

Email:

- Website:

Fire District Sign Off

A copy of your proposed plans and plat map will be required at the time of Fire District review.

Applicant Name: House of The Lord Church
Phone number: 509-671-2493 Email: MaryAnn@MaryAnnJones.Net
BLP#: 2025-0768
Parcel number (RP#): RP55N05W063201A
Project Address: 36245 Hwy. 41 Oldtown, ID. 83822
Platted Lot: Yes ☐ No ☒

Subdivision Name: _____

Block & Lot: _____

Fire District: West ~~Bonneville~~ Pend Oreille Fire Dist.

(Fire District use below)

Requirements: _____

Cistern/Storage Tank: ☐ Fire Suppression: ☐ Sprinkler System: ☐

Other: _____

Approved: Yes ☐ No ☒

Fire District Signature: Chief Jennie Painter Date: _____

Comments:



Wpfd District 1 <wpofd1@gmail.com>

Fwd: House of the Lord plans

1 message

Jamie Painton <wpofd1.jamie@gmail.com>

Wed, Jul 9, 2025 at 11:46 AM

To: Wpfd District 1 <wpofd1@gmail.com>

----- Forwarded message -----

From: **Debbie Carpenter** <debbie.carpenter@doi.idaho.gov>

Date: Wed, Jul 9, 2025 at 10:17 AM

Subject: House of the Lord plans

To: wpofd1.jamie@gmail.com <wpofd1.jamie@gmail.com>

Chief Painton,

Our office has looked at the submitted plans for the new House of the Lord church on Highway 41.

This building will require an automatic sprinkler system, as specified in the 2018 *International Fire Code*:

903.2.1.3 Group A-3

An automatic sprinkler system shall be provided throughout stories containing Group A-3 occupancies and throughout all stories from the Group A-3 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The *fire area* exceeds 12,000 square feet (1115 m²).
2. The *fire area* has an *occupant load* of 300 or more.
3. The *fire area* is located on a floor other than a *level of exit discharge* serving such occupancies.

This building will require an approved fire alarm system, as specified in the 2018 *International Fire Code*:

907.2.1.1 System initiation in Group A occupancies with an occupant load of 1,000 or more.

Activation of the fire alarm in Group A occupancies with an *occupant load* of 1,000 or more shall initiate a signal using an emergency voice/alarm communications system in accordance with Section 907.5.2.2.

907.5 Occupant notification systems.


A fire alarm system shall annunciate at the fire alarm control unit and shall initiate occupant notification upon activation, in accordance with Sections 907.5.1 through 907.5.2.3.3. Where a fire alarm system is required by another section of this code, it shall be activated by:

1. Automatic fire detectors.
2. Automatic sprinkler system waterflow devices.
3. Manual fire alarm boxes.
4. Automatic fire-extinguishing systems.

The exits for the building are adequate for the occupant loads listed.

Thanks,

Debbie



Deputy State Fire Marshal

Debbie Carpenter, ICC-FI1

2005 Ironwood Parkway, Suite 143

Coeur d'Alene, ID 83814

Phone: (208) 769-1447

Cell: (986) 217-6684

Email: debbie.carpenter@doi.idaho.gov

image001.png
1K



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] MOD0004-25 comments

1 message

Wpfd District 1 <wpofd1@gmail.com>

Tue, Jul 8, 2025 at 11:26 AM

To: planning@bonnercountyid.gov

The fire department has not seen any engineered plans on this modification.
Prior to approving an updated building permit, we need to see the plans and occupancy load and evaluate the need for an automatic sprinkler system, an automatic alarm system, egress out of the building, and egress to the highway.
West Pend Oreille Fire District
Chief Jamie Painton



Dylan Young <dylan.young@bonnercountyid.gov>

Bonner County Planning - File MOD0004-25 Agency Review

Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>
To: Bonner County Planning Department <planning@bonnercountyid.gov>

Thu, Jul 3, 2025 at 1:20 PM

Hi Dylan,

The Idaho Department of Fish and Game does not have any comments to submit for this application.

Thank you for the opportunity to review and comment,

Merritt Horsmon

Regional Technical Assistance Manager

Panhandle Region

2885 W. Kathleen Ave.

[Coeur d'Alene, ID 83815](#)

208.769.1414 office

208.251.4509 mobile

merritt.horsmon@idfg.idaho.gov



From: Bonner County Planning Department <planning@bonnercountyid.gov>

Sent: Tuesday, July 01, 2025 8:54 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Carrol Stejer <CASTEJER@gmail.com>; Bell, Chace

<Chace.Bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spiritleakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Kootenai <cityclerk@cityofkootenai.org>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spiritleakeid.gov; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; dbrown@idl.idaho.gov; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dave Schuck <dave.schuck@bonnercountyid.gov>; Dean Davis <deandavis@sd83.org>; Kristie May <Kristie.May@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejduhn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Dan Everhart <Dan.Everhart@ishs.idaho.gov>; DEQ Comments <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <robert.beachler@itd.idaho.gov>; ITD - Stacy Simkins <stacy.simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Jamie Brown <jamieb@inlandpower.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <jason.kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; joekren@sd83.org; Jordan Brooks <coolinsewer@gmail.com>; Karen Quenell <kquenell@northsidefire.org>; KayLeigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Ken Flint <ken_flint@tcenergy.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lacedewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHApplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone.legg@itd.idaho.gov; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <epfldchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>

Cc: Janna Brown <janna.brown@bonnercountyid.gov>; Jeannie Welter <jeannie.welter@bonnercountyid.gov>; Dylan Young <dylan.young@bonnercountyid.gov>

Subject: Bonner County Planning - File MOD0004-25 Agency Review

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments **BEFORE** you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

[Quoted text hidden]

NOTICE OF PUBLIC HEARING



I hereby certify that a true and correct copy of this "Notice of Public Hearing" was digitally transmitted or mailed (postage prepaid) on this **1st** day of **July 2025**.

Dylan Young

Dylan Young, Hearing Coordinator

This notice was mailed to political subdivisions, property owners within 300 feet of the subject property, and the media on **Tuesday, July 1, 2025**.

NOTICE IS HEREBY GIVEN that the Bonner County Zoning Commission will hold a public hearing at **5:30 pm** on **Thursday July 24, 2025** in the Bonner County Administration Building, 1500 Highway 2, Sandpoint, Idaho, by Zoom teleconference, and YouTube Livestream to consider the following request:

File MOD0004-25 – Modification of Terms–Church

The applicants are requesting a modification to C650-99, to include the new lot size, and the construction of a larger church. The 10-acre parcel is zoned Rural 10(R-10). The project site is located off State Highway 41 in Section 6, Township 55 North, Range 5 West, Boise-Meridian. The project is located within the West Pend Oreille Fire District.

For details regarding this application, Zoom teleconference, or YouTube livestream, visit the Planning Department web site at www.bonnercountyyid.gov/departments/Planning. Staff reports are available online or may be viewed at the planning department approximately a week before the scheduled hearing.

Written statements must be submitted to the planning department record no later than seven (7) days prior to the public hearing. Written statements not exceeding one standard letter sized, single spaced page may be submitted at the public hearing. Statements can be sent to the Bonner County Planning Department at 1500 Highway 2, Suite 208, Sandpoint, Idaho 83864; faxed to 866-537-4935 or e-mailed to planning@bonnercountyyid.gov. The referenced start time stated above reflects the beginning of the hearing. Specific file start time and hearing duration vary.

During the hearing for this application, the public will be given an opportunity to provide testimony and/or evidence regarding how the proposal does or does not comply with the applicable approval criteria of the Bonner County Revised Code. At the close of the public hearing, the governing body will make a decision on the application that may include, but is not limited to, approval, denial, remand, or continuance of the public hearing. Any person needing special accommodations to participate in the public hearing should contact the Bonner County Planning Department at (208) 265-1458 at least 48 hours prior to the scheduled hearing.

If you have no comment or response, you may indicate below and return this form to the Planning Department.

NO COMMENT

Name

Date

Kootenai-Tonderay Sewer District *7/3/25*

Out of District Boundaries