



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] Re: Bonner County Planning - S0001-25 Agency Review - Short Plat - River Estates

1 message

Bonner County History Museum <hannah@bonnercountyhistory.org>

To: Bonner County Planning <planning@bonnercountyid.gov>

No comment

Hannah Combs

Bonner County Historical Society

On Wed, Apr 30, 2025 at 11:13 AM Bonner County Planning <planning@bonnercountyid.gov> wrote:

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details

Thank you,
Janna Brown, Administrative Assistant III
Bonner County Planning Department
208-265-1458 ext - 1252



Janna Brown <janna.brown@bonnercountyid.gov>

Re: Bonner County Planning - S0001-25 Agency Review - Short Plat - River Estates

1 message

Matt Mulder <matt.mulder@bonnercountyid.gov>

To: Bonner County Planning <planning@bonnercountyid.gov>

The Road & Bridge Department has the following comment:

On the plat, show Peninsula Rd as a County maintained public road, show the right-of-way width (appears to be 60ft), and add a note regarding how the ROW was established (instrument #

-Matt Mulder, PE
Staff Engineer
Bonner County Road & Bridge
208-255-5681 ext 1

On Wed, Apr 30, 2025 at 11:13 AM Bonner County Planning <planning@bonnercountyid.gov> wrote:

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details

Thank you,
Janna Brown, Administrative Assistant III
Bonner County Planning Department
208-265-1458 ext - 1252



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Deerfield Subdivision - S0001-25

1 message

Bill Dean <bdean@sandpointidaho.gov>

Mon, May 12, 2025 at 4:36 PM

To: Jake Gabell <jake.gabell@bonnercountyid.gov>, Jason Welker <jwelker@sandpointidaho.gov>

Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>, Janna Brown <janna.berard@bonnercountyid.gov>, Jason Johnson <jason.johnson@bonnercountyid.gov>

Hi Jake, thanks again for routing the Deerfield application to us for review/comment. Our City Council addressed this at last Wednesday's CC mtg and below is the excerpt from the DRAFT minutes which will go to CC next week for approval. Our staff report is [here](#):

Citing a conflict as the applicant to Bonner County for this development, Councilor Howarth recused himself from this matter and left the dais.

City Planner Bill Dean reviewed his staff report and packet materials with the Council and, along with Mayor Grimm and Mr. Jones, fielded questions. Council approved the comments from the City to Bonner County regarding the Deerfield Subdivision Application, as composed by City staff, with the following amendments:

- a. Include a suggestion for a right-of-way dedication on the corners of Lots 9 and 10 in Block 1 for future connectivity to the south and/or west.
- b. Include a suggestion that any access point included in this development onto the property owned by the City of Sandpoint to the east of this development be constructed from public right-of-way stubbed to the City property.

Motion made by Councilor Schreiber, Seconded by Councilor Duquette.

Voting Yea: Councilor Ruehle, Councilor Aispuro, Councilor Dick, Councilor Schreiber, Councilor Duquette

Abstaining: Councilor Howarth

The minutes will be posted next week after CC approval. Do you need anything else from us? We're happy to further discuss. We'd appreciate you sharing our City Council's requests, as described above and in the linked staff report with the Commissioners.

Thanks, Bill

**City of Sandpoint Planning****Bill Dean** | City Planner

Office | (208)265-1480

1123 Lake St. Sandpoint,

ID 83864

From: Jake Gabell <jake.gabell@bonnercountyid.gov>

Sent: Thursday, April 17, 2025 3:56 PM

To: Jason Welker <jwelker@sandpointidaho.gov>; Bill Dean <bdean@sandpointidaho.gov>

Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>; Janna Brown <janna.berard@bonnercountyid.gov>; Jason Johnson <jason.johnson@bonnercountyid.gov>

Subject: Deerfield Subdivision - S0001-25

[Caution] This email originated from outside the City of Sandpoint organization. **Do not** click on links or open attachments unless you recognize the sender and know it's safe. When in doubt contact the [IT Department](#)

Good afternoon Gentlemen,

Here is the link to the Deerfield subdivision application and associated documents.

I understand that the applicant is pushing for this to be added to the May Zoning Commission agenda. To accomplish this, we would need something in writing stating that the City is waiving the 40-day notice requirement found in the current ACI agreement. In order to meet our other noticing requirements, we would have to send a public notice to the paper by Tuesday of next week.

I'm completely fine waiting to hold this hearing until June, as currently planned, but if the City is willing to waive its 40-day notice period, then we could hold the hearing sooner. Please note that per Bonner County Code, the Zoning Commission cannot make a decision on a preliminary plat. They make a recommendation to the BOCC, who will hold another hearing and make a decision on this file in the preliminary plat phase.

<https://www.bonnercountyid.gov/FileS0001-25>

Jake Gabell, Director

Bonner County Planning Department

1500 Highway 2, Suite 208

Sandpoint, ID 83864

Phone: 208-265-1458



Staff Report

To: City Council

From: Bill Dean, City Planner; Brandon Staglund, City Engineer; Maeve Nevins-Lavtar, Parks Planning and Development Manager

Report: April 23, 2025

Meeting: May 7, 2025

Item: City's Area of Impact: Bonner County Application S0001-25 Deerfield Subdivision

Applicant: Deerfield LLC – Rick Howarth / HMH Engineering – Dan Tadic

Please Note: The Application and all materials related to this request are provided on the City's website at:
www.sandpointidaho.gov/currentprojects

1) Executive Summary

An application to subdivide a 32.67-acre parcel into twenty-four (24) 1-acre lots for residential development has been filed with the Bonner County Planning Department. The property in question is located on the south side of Baldy Mountain Rd, partially abutting the City-owned 32-acre undeveloped property commonly known as Baldfoot Disc Golf Course, whose address is 10076 Baldy Mountain Rd. The proposed subdivision is located in Bonner County and within the City's (current) Area of City Impact. Pursuant to the written agreement between Bonner County and the City related to managing the Area of City Impact, applications submitted to the County for development and subdivisions are routed to the City for the opportunity to comment (Attachment A: 1994 Agreement with County). This agenda item satisfies that opportunity, and provides recommendations to the County, related to the subdivision (Attachment B: Application submitted to County). The authority to formally act on the subdivision (approve or deny) rests solely with Bonner County. This staff report contains suggested comments for the City Council to consider submitting to Bonner County, reflecting City policy and codes applicable to subdivisions within the City, acknowledging that the purpose of the Area of City Impact is to identify and potentially entertain future annexation of property located in the Area of City Impact. No application for annexation has been filed, and it is staff's understanding that there is no intent on behalf of the property owner to pursue future annexation to the City.

2) Introduction and Background

Deerfield LLC is requesting approval of a preliminary plat on parcel (RP57N02W164952A) consisting of approximately 33-acres (Attachment C: Deerfield Preliminary Plat). The property is located on the south side of Baldy Mountain Rd, west of the City-owned parcel commonly known as Baldfoot Disc Golf Course, whose address is 10076 Baldy Mountain Rd (Figure 1). The proposed subdivision seeks to create twenty-four lots, 23 lots approximately 1-acre in size, one 3-acre parcel and an approximately 2-acre storm water tract. The proposal also includes a new paved public roadway providing access to each lot within a 60-foot right-of-way (ROW). The new road would contain within the ROW two 12-foot wide travel lanes and 15-feet of ditches on either side along with a 1-foot gravel curb adjacent to the paved lanes.

The property is situated within the County's Suburban Zone district (IG) zone, as are all adjoining properties (Figure 2), with the exception of the City's property which is within the City limits and zoned Residential Single-Family

(RS). All lots will have access and frontage on a public right of way.

Preliminary plats set forth the basic information for the County Commissioners to determine if the proposed subdivision complies with the applicable requirements of the Bonner County Code and Idaho Statutes. Upon approval of a preliminary plat by the County, a permit for public infrastructure improvements may be issued and once complete and accepted by the County, a final plat may be approved by the County and recorded. A final plat is necessary to create and sell new lots.

On April 17, 2025, the application referral was brought to staff's attention. Staff placed this item on the May 6, 2025 agenda for Planning Commission review and potential comment. Any comments received by Planning Commission will be shared with City Council at the May 7, 2025 City Council meeting.




Figure 1 - Vicinity Map



Figure 2 - Zoning Map





Figure 3 - Preliminary Plat

3) Preliminary Plat Requirements – Basis for City Review

The City standards for subdivision platting differ substantially from those in Bonner County as relates to roads and public utilities. For a subdivision in the City, Title 10, Chapter 1 of Sandpoint City Code establishes the subdivision and new development standards and regulations for preliminary plats. In terms of reviewing this plat, the approach taken by City staff was to consider recommendations to the County based on several of the standards contained in Title 10 of Sandpoint City Code, and City policy documents. Below is a list of typical zoning and infrastructure components of a Preliminary Plat and a recommendation related to each component.

Lot Size: It is staff's understanding that County regulations allow for 1-acre lots where water service is available. The policy in the City's Comprehensive Plan identifies this area as Low-Density Clustered Residential which is:

“.. a low-density residential development pattern. Areas designated as the Wildland Urban Interface (WUI) by the forest service are also found in this area. This development pattern encourages preservation of wildlife habitat, riparian corridors, and open space through the utilization of cluster development that prefers congregation of dwelling units at slightly higher density in exchange for protection of larger areas of open space and wildfire risk areas. This pattern allows for safe development with adequate space to accommodate an adjacent floodplain or wetland areas while also providing access to recreation. This model of development also promotes connectivity through trails and connected street networks. LDCR is located primarily in the northeast area of the city, adjacent to the City of Ponderay.”

City staff has no recommendations related to lot size.

Access to Bike/Pedestrian Trails: The application states the following on page 3:

“The HOA will have access to the open space/stormwater tract which fronts Syringa Creek. The HOA may choose to install an informal gravel trail along the northern portion of the tract to allow for pedestrian access from Deerfield to the City of Sandpoint owned disc golf property which lies directly to the east of the open space/stormwater tract. This short trail would be utilized by residents only with no public parking provided. This will be dependent on and coordinated with the City of Sandpoint.”

City staff recommends that the Owners Certificate and notes on the Preliminary Plat include reference to the intended access across the tract to the City's property. Staff further recommends that prior to Final Plat a revocable pedestrian access easement for benefit of HOA, including the following features: a minimum 4-foot wide gate – pedestrian and bicycle access only, educational signage from east to west stating “private property”, and signage stating “no motorized vehicles allowed on public property”, and a dog waste station on HOA side of gate.

Additional considerations for trail design in wildlife-rich areas which could be included on the Final Plat or placed as a condition of approval for inclusion in HOA regulations related to the open space/stormwater tract include: avoid critical wildlife habitats, consider circumventing sensitive wildlife or native plant habitats to minimize disturbances; align trail along existing natural or human-made edges to reduce habitat fragmentation; determine appropriate trail width and surface materials that accommodate intended use while minimizing environmental impact. The area suggested may have seasonal flooding, consider utilizing trail hardening materials in the construction of access trail with a firm, stable, compacted surface, ensure trail meets ADA Accessible guidelines to accommodate users of all abilities; incorporate safety measures such as vegetation clearance trail corridor of 6 to 10 feet wide and a minimum of 10 feet high clearance of any overhead or adjacent vegetation for improved safety and site lines, and consider utilizing reflective paint on the signage or solar lighting to identify access point. Re-seeding after construction with native revegetation and native seed mixtures are highly recommended to reduce invasive plant species.

Water: Water is being provided by Syringa Heights Water District, and Fire flow demands will be met with an on-site water tank. **City staff has no recommendations related to water.**

Sewer: Each lot is required to have an on-site septic system permitted and approved through Idaho Panhandle Health; no municipal sewer system is available. **City staff has no recommendations related to water.**

Storm drainage: Subdivisions in Bonner County are required to comply with the stormwater requirements of Bonner County Code 12-724.1 and 12-724.2. **City staff has no recommendations related to stormwater beyond what is required to comply with Bonner County Code**

Roads: Bonner County Road and Bridge has separate standards related to the requirements of road construction of new public roads. City staff has no recommendation related to the construction of the new internal road. The City of Sandpoint Multimodal Transportation Master Plan does include a “long term” capital improvement project to widen Baldy Mountain Road between Great Northern and Boyer Avenue, which includes a possible multiuse path or sidewalk on both sides of Baldy Mountain Road. **Bonner County may consider requiring a multiuse pathway along the south side of Baldy Mountain Road adjacent to this subdivision for potential future connection to the City of Sandpoint’s multimodal network.**

4) City Council Action

Per the agreement between the City and County, the City has the opportunity to comment, whereas the County takes action which may or may not include City recommendations. By approving this agenda item, the City Council will be directing the comments listed in the staff report for consideration by the County as they process the Preliminary Plat for the Deerfield project.

5) Attachments

- A: Area of City Impact 1994 Agreement with County
- B: Deerfield Subdivision Application to Bonner County
- C: Deerfield Preliminary Plat



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

1 message

DEQ Comments <deqcomments@deq.idaho.gov>

Wed, Jun 18, 2025 at 3:11 PM

To: Bonner County Planning <planning@bonnercountyid.gov>

Good Afternoon,

Thank you for providing the opportunity to comment. DEQ has no environmental impact comments for the project listed above at this stage of development.

Thank you,

Idaho Department of Environmental Quality
2110 Ironwood Parkway, Coeur d'Alene, Idaho 83814
Office Line: 208.769.1422

www.deq.idaho.gov

Our mission: To protect human health and the quality of Idaho's air, land, and water.

From: Bonner County Planning <planning@bonnercountyid.gov>

Sent: Wednesday, May 28, 2025 11:51 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Bell, Chace <Chace.Bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spirittlakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spirittlakeid.gov; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; dbrown@idl.idaho.gov; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dean Davis <deandavis@sd83.org>; Kristie May <Kristie.May@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejduhn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; Dan Everhart <Dan.Everhart@ishs.idaho.gov>; DEQ Comments <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <robert.beachler@itd.idaho.gov>; ITD - Stacy Simkins <stacy.simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Jamie Brown <jamieb@inlandpower.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <jason.kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; joekren@sd83.org; Jordan Brooks <coolinsewer@gmail.com>; Kayleigh Miller <kmliller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Ken Flint

<ken_flint@tcenergy.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lacledewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHapplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; sandpointairport@gmail.com; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone.legg@itd.idaho.gov; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <epfldchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>
Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>; Jessica Montgomery <jessica.montgomery@bonnercountyid.gov>
Subject: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

Janna Brown, Administrative Assistant III

Bonner County Planning Department

208-265-1458 ext - 1252



Jason Johnson <jason.johnson@bonnercountyid.gov>

Fwd: [EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Short Plat - River Estates

Katie Hansen <katie.hansen@bonnercountyid.gov>

Thu, May 8, 2025 at 2:09 PM

To: Jason Johnson <jason.johnson@bonnercountyid.gov>, Bonner County Planning <planning@bonnercountyid.gov>

Thank you,

Katie Hansen

Compliance/Permit Manager
Bonner County Planning Department
[1500 Hwy 2, Suite 208](#)
[Sandpoint, ID 83864](#)
Phone: 208.265.1458
Cell: 208.946.3238

----- Forwarded message -----

From: **DEQ Comments** <deqcomments@deq.idaho.gov>

Date: Thu, May 8, 2025 at 2:02 PM

Subject: [EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Short Plat - River Estates

To: Bonner County Planning <planning@bonnercountyid.gov>

Good Afternoon,

Thank you for providing the opportunity to comment. DEQ has no environmental impact comments for the project listed above at this stage of development.

Thank you,

Idaho Department of Environmental Quality
[2110 Ironwood Parkway, Coeur d'Alene, Idaho 83814](#)
Office Line: 208.769.1422

www.deq.idaho.gov

Our mission: To protect human health and the quality of Idaho's air, land, and water.

From: Bonner County Planning <planning@bonnercountyid.gov>

Sent: Wednesday, April 30, 2025 11:13 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Bell, Chace <Chace.Bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spirittlakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoverydaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spirittlakeid.gov; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Connie Nelson <connien@inlandpower.com>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; dbrown@idl.idaho.gov; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dean Davis <deandavis@sd83.org>; Kristie May <Kristie.May@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejdunn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; Dan Everhart <Dan.Everhart@ishs.idaho.gov>; DEQ Comments <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <robert.beachler@itd.idaho.gov>; ITD - Stacy Simkins <stacy.simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <jason.kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; joekren@sd83.org; Jordan Brooks <coolinsewer@gmail.com>; KayLeigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lacledewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EApplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; sandpointairport@gmail.com; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone.legg@itd.idaho.gov; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi

<epbfdchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>
Cc: Kyle Snider <kyle.snider@bonnercountyid.gov>; Alexander Feyen <alexander.feyen@bonnercountyid.gov>
Subject: Bonner County Planning - S0001-25 Agency Review - Short Plat - River Estates

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments **BEFORE** you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

Janna Brown, Administrative Assistant III

Bonner County Planning Department

208-265-1458 ext - 1252



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

1 message

D1Permits <D1Permits@itd.idaho.gov>

Wed, May 28, 2025 at 2:40 PM

To: Bonner County Planning <planning@bonnercountyid.gov>

ITD has no comment.

Have a nice day!

**Kimberly Hobson***Project Coordinator**Innovation Steward***District 1****Work:** 208.772.8079**Email:** kimberly.hobson@itd.idaho.gov**Website:** itd.idaho.gov**Work schedule:** M-W-Th-F 6AM- 4:30 PM**From:** Bonner County Planning <planning@bonnercountyid.gov>**Sent:** Wednesday, May 28, 2025 11:51 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Corp - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Chace Bell <chace.bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spirittlakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spirittlakeid.gov; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; Dan Brown <dbrown@idl.idaho.gov>; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dean Davis <deandavis@sd83.org>; DEQ - Kristie McEnroe

<kristie.mcenroe@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejduhn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; ID State Historical Society - Dan Everhart <dan.everhart@ishs.idaho.gov>; Idaho Department of Environmental Quality <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <Robert.Beachler@itd.idaho.gov>; Stacy Simkins <Stacy.Simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Jamie Brown <jamiieb@inlandpower.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <Jason.Kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; Joe Kren <joekren@sd83.org>; Jordan Brooks <coolinsewer@gmail.com>; KayLeigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Ken Flint <ken_flint@tcenergy.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lactedewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHapplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; sandpointairport@gmail.com; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone Legg <Symone.Legg@itd.idaho.gov>; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <epldchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>
Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>; Jessica Montgomery <jessica.montgomery@bonnercountyid.gov>
Subject: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

5/28/25, 4:28 PM

Bonner County Mail - [EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

Janna Brown, Administrative Assistant III

Bonner County Planning Department

208-265-1458 ext - 1252



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

1 message

Symone Legg <Symone.Legg@itd.idaho.gov>
To: Bonner County Planning <planning@bonnercountyid.gov>
Cc: Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>

Wed, May 28, 2025 at 3:09 PM

ITD Permits has no comment.

Thank you,

Symone Legg | Project Coordinator**Idaho Transportation Department** | D1 Traffic/Permits

Ext: 208.772.8073 Dept: 208.772.1297

Email: symone.legg@itd.idaho.gov | itd.idaho.gov*Enhancing quality of life through transportation*

Work schedule: Monday - Thursday 6AM- 4:30PM

From: Bonner County Planning <planning@bonnercountyid.gov>**Sent:** Wednesday, May 28, 2025 11:51 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Chace Bell <chace.bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spirittlakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoverydaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spirittlakeid.gov; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; Dan Brown <dbrown@idl.idaho.gov>; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dean Davis <deandavis@sd83.org>; DEQ - Kristie McEnroe <kristie.mcenroe@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejduhn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Horsmon,Merriitt <merriitt.horsmon@idfg.idaho.gov>; ID State Historical Society - Dan Everhart <dan.everhart@ishs.idaho.gov>; Idaho Department of Environmental Quality <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <Robert.Beachler@itd.idaho.gov>; Stacy Simkins <Stacy.Simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Jamie Brown <jamieb@inlandpower.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <Jason.Kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; Joe Kren <joekren@sd83.org>; Jordan Brooks <coolinsewer@gmail.com>; KayLeigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Ken Flint <ken_flint@tcenergy.com>; Kenny Huston

<kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lactedewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHApplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; sandpointairport@gmail.com; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone Legg <Symone.Legg@itd.idaho.gov>; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <epfldchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>

Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>; Jessica Montgomery <jessica.montgomery@bonnercountyid.gov>

Subject: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

Janna Brown, Administrative Assistant III

Bonner County Planning Department

208-265-1458 ext - 1252



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

1 message

Robert Beachler <Robert.Beachler@itd.idaho.gov>
To: Bonner County Planning <planning@bonnercountyid.gov>

Thu, May 29, 2025 at 6:39 AM

No Comment from the Idaho Transportation Department.

Robert Beachler

District 1 Planning Program Manager

Idaho Transportation Department

600 W. Prairie Ave

Coeur d'Alene, ID 83815

robert.beachler@itd.idaho.gov

(208) 772-1216

Office Hours M-TH 6-4:30

From: Bonner County Planning <planning@bonnercountyid.gov>

Sent: Wednesday, May 28, 2025 11:51 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Chace Bell <chace.bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spirittlakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spirittlakeid.gov; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; Dan Brown <dbrown@idl.idaho.gov>; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dean Davis <deandavis@sd83.org>; DEQ - Kristie McEnroe <kristie.mcenroe@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn <Frankiejedunn@hotmail.com>; Fritz Broschet

<outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; ID State Historical Society - Dan Everhart <dan.everhart@ishs.idaho.gov>; Idaho Department of Environmental Quality <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <Robert.Beachler@itd.idaho.gov>; Stacy Simkins <Stacy.Simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Jamie Brown <jamieb@inlandpower.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <Jason.Kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; Joe Kren <joeKren@sd83.org>; Jordan Brooks <coolinsewer@gmail.com>; Kayleigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Ken Flint <ken_flint@tcenergy.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lacledewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHApplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; sandpointairport@gmail.com; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone Legg <Symone.Legg@itd.idaho.gov>; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <epfldchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>

Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>; Jessica Montgomery <jessica.montgomery@bonnercountyid.gov>

Subject: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

Janna Brown, Administrative Assistant III

Bonner County Planning Department

208-265-1458 ext - 1252



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] RE: Bonner County Planning - S0001-25 Agency Review - Short Plat - River Estates

1 message

Robert Beachler <Robert.Beachler@itd.idaho.gov>
To: Bonner County Planning <planning@bonnercountyid.gov>

Mon, May 5, 2025 at 3:12 PM

No Comment from the Idaho Transportation Department.

Robert Beachler
District 1 Planning Program Manager
Idaho Transportation Department
600 W. Prairie Ave
Coeur d'Alene, ID 83815
robert.beachler@itd.idaho.gov
(208) 772-1216
Office Hours M-TH 6-4:30

From: Bonner County Planning <planning@bonnercountyid.gov>

Sent: Wednesday, April 30, 2025 11:13 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>; Amber Burgess <clerk@ebsewerdistrict.com>; Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>; Avista Copr - Jay West <jay.west@avistacorp.com>; Avista Corp - Peggy George <peggy.george@avistacorp.com>; Becky Meyer <becky.meyer@lposd.org>; Bill Berg <billb@bbsewer.org>; Bonner County Assessors <assessorsgroup@bonnercountyid.gov>; BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>; Brenna Garro <Brenna.Garro@oer.idaho.gov>; Bryan Quayle <quaylelanduseconsulting@gmail.com>; Chace Bell <chace.bell@idwr.idaho.gov>; Chief Debbie Carpenter <chief@spirittlakefire.com>; City of Clark Fork <city@clarkforkidaho.org>; City of Dover <cityclerk@cityofdoveridaho.org>; City of East Hope Franck <easthope.city@gmail.com>; City of Hope <hopecityclerk@gmail.com>; City of Oldtown <cityofoldtown@hotmail.com>; City of Priest River <layers@priestriver-id.gov>; City of Sandpoint Planning <cityplanning@sandpointidaho.gov>; cityclerk@spirittlakeid.gov; Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>; Connie Nelson <connien@inlandpower.com>; Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>; Craig Hill <craighill@hillsresort.com>; D1Permits <D1Permits@itd.idaho.gov>; Dan Brown <dbrown@idl.idaho.gov>; Dan McCracken <Dan.McCracken@deq.idaho.gov>; Dan Scholz <dan.scholz@nli.coop>; Dean Davis <deandavis@sd83.org>; DEQ - Kristie McEnroe <kristie.mcenroe@deq.idaho.gov>; East Bonner Library <Amanda@ebonnerlibrary.org>; East Priest Lake Fire District <eastpriestlakefd@gmail.com>; Erik Sjoquist <esjoquist@idl.idaho.gov>; Federal Aviation Administration <Heather.pate@faa.gov>; Frankie Dunn

<Frankiejduhn@hotmail.com>; Fritz Broschet <outletbaysewer@gmail.com>; Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>; Gavin Gilcrease <ggilcrease@sandpointidaho.gov>; Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>; ID State Historical Society - Dan Everhart <dan.everhart@ishs.idaho.gov>; Idaho Department of Environmental Quality <deqcomments@deq.idaho.gov>; Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>; Robert Beachler <Robert.Beachler@itd.idaho.gov>; Stacy Simkins <Stacy.Simkins@itd.idaho.gov>; Jack Schenck <Jack.schenck@vyvebb.com>; Janice Best <janicesb@televar.com>; Jason Johnson <jason.johnson@bonnercountyid.gov>; Jason Kimberling <Jason.Kimberling@itd.idaho.gov>; Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>; Jessie Roe <BWSD637@gmail.com>; Joe Kren <joekren@sd83.org>; Jordan Brooks <coolinsewer@gmail.com>; Kayleigh Miller <klmiller@ponderay.org>; kbsd sewer <kbsdpl@hotmail.com>; Kenny Huston <kenny.huston@oer.idaho.gov>; Kim Hoodenpyle <kjh5345@gmail.com>; Kim Spacek <kimspacek@sd83.org>; Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>; Laclede Water District <info@lacedewaterdistrict.org>; Lakeland Joint School District #272 <cpursley@lakeland272.org>; Lisa Rosa <hr@ebonnerlibrary.org>; Matt Diel <matt.diel@lposd.org>; Midas Water <midaswatercorp@gmail.com>; Mike Ahmer <mahmer@idl.idaho.gov>; Mike Schacht <firedept@clarkforkidaho.org>; Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>; Navy - Glynis Casey <glynis.casey@navy.mil>; North of the Narrows Fire District <Huckbay2501@gmail.com>; Northern Lights <kristin.mettke@nli.coop>; Northern Lights - Clint Brewing <clint.brewington@nli.coop>; Northside Water and Syringa Heights Water Association <allwater49@outlook.com>; Oden Water Association - Carla Poelstra <odenwater@gmail.com>; Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>; PHD <EHApplications@phd1.idaho.gov>; Priest Lake Public Library District <plplibrary@hotmail.com>; Richard Hash <Rich.hash2022@gmail.com>; Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>; Ryan Zandhuisen <rzandhuisen@idl.idaho.gov>; Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>; Sagle Valley Water & Sewer District <markc@smartplugs.com>; Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>; Sam Ross <sam.ross@nli.coop>; sandpointairport@gmail.com; Sarah Gilmore <sgilmore@sandpointidaho.gov>; School District 84 Transportation - James Koehler <james.koehler@lposd.org>; SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>; Selkirk Association of Realtors <danielle@selkirkaor.com>; Selkirk Recreation District <elgar@whoi.edu>; Sheryl Austin <granitereeder@gmail.com>; SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>; Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>; Steve Elgar <selgar@mac.com>; Superintendent School Dist 84 <kelly.fisher@lposd.org>; Symone Legg <Symone.Legg@itd.idaho.gov>; TC Energy / TransCanada <US_crossings@tcenergy.com>; Teresa Decker <Huckleberryhoa@gmail.com>; Teresa Decker <huckbayutilities01@gmail.com>; Teresa Zamora <utilities@stoneridgeidaho.com>; Theresa Wheat <theresa@kootenai.org>; Tim Ventress <chventresswplvfd@hotmail.com>; Timberlake Fire District <Kwright@timberlakefire.com>; Tom Renzi <epfldchief@gmail.com>; US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>; West Bonner Library <meagan@westbonnerlibrary.org>; West Pend Oreille Fire District <wpofd1@gmail.com>
Cc: Kyle Snider <kyle.snider@bonnercountyid.gov>; Alexander Feyen <alexander.feyen@bonnercountyid.gov>
Subject: Bonner County Planning - S0001-25 Agency Review - Short Plat - River Estates

CAUTION: This email originated outside the State of Idaho network. Verify links and attachments BEFORE you click or open, even if you recognize and/or trust the sender. Contact your agency service desk with any concerns.

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Thank you,

Janna Brown, Administrative Assistant III

Bonner County Planning Department

208-265-1458 ext - 1252



Public Health
Prevent. Promote. Protect.
Panhandle Health District

Panhandle Health District

Healthy People in Healthy Communities

Environmental Health
2101 W. Pine St.
Sandpoint ID 83864
Phone: 208-265-6384
Fax: 208-265-8550
www.phd1.idaho.gov

May 2, 2025

198 Floyds Road
Sagle Idaho 83860

RE: UPDATED – Syringa Estates, #24-09-08209

To All Concerned:

The residential subdivision known as *Syringa Estates* consisting of 25 lots on 33 acres located in Township 57 North, Range 02 West, Section 16 within Bonner County in the State of Idaho has been reviewed by Panhandle Health District (PHD). PHD will grant final plat approval when the following conditions are satisfied:

- Update PHD application with current subdivision name and any other information that may have changed since application submittal, i.e. number of lots. **(Incomplete)**
- PHD must receive a letter from the Department of Environmental Quality (DEQ) or a Qualified Licensed Professional Engineer (QLPE) stating water and sewer services for *Syringa Estates* meet the State of Idaho Standards. **(Incomplete, see 3.11 & 3.12 in the Idaho State Land SOP)**
- PHD must receive a letter from *Syringa Water* stating they have the capacity and willingness to supply water/sewer to all 25 lots in the *Syringa Estates*. **(Complete)**
- Test holes must be dug and approved drainfield sites must be located for all lots within the subdivision. **(Complete)**
- The water source must be stated on the plat as part of the owner's certificate block as required by Idaho Code §50-1334. **(Incomplete)**
- PHD will provide the applicable language for the Sanitary Restriction/Certificate of Approval as required by Idaho Code §50-1326 to §50-1329. This must be placed on the face of the plat. **(Contact PHD)**
- All shallow injection wells (drywells) must be registered with PHD and corresponding fees paid. **(None proposed)**
- Copies of the plat including signature page(s) must be supplied to PHD. **(Incomplete)**
- All fees pertinent to PHD's subdivision review process must be paid. **(Complete)**

If the above conditions are satisfied PHD will lift the sanitary restrictions when the final plat/mylar is signed. Please note that plat approval does not guarantee these lots are buildable. If you have any questions or require additional information please call Panhandle Health District.

PHD recommends that the suitable drainfield sites are located on the face of the plat. It is the owners responsibility to protect and preserve the approved drainfield and replacement areas at all times.

Sincerely,

Amanda J Cerise
Registered Environmental Health Specialist

cc: Bonner County Planning Department - planning@bonnercountyid.gov
DEQ - croplansubmittal@deq.idaho.gov
Syrina Water District – drinkard.s@gmail.com
Dan Tadic – dtadic@hnh-llc.com



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] File S0001-25 - Long Plat - Deerfield

1 message

Kathryn Kolberg <KKolberg@phd1.idaho.gov>

Wed, Jun 18, 2025 at 3:36 PM


To: Bonner Planning <planning@bonnercountyid.gov>

Cc: Amanda Cerise <acerise@phd1.idaho.gov>, CRO Plan Submittal <CROPlanSubmittal@deq.idaho.gov>

Hi –

Please see attached for PHD comments dated 6.18.25 and 5.2.25 regarding the proposed Deerfield plat and upcoming Zoning Commission Hearing.

Regards,
Kathryn

 Public Health Prevent. Promote. Protect. Panhandle Health District	Kathryn Kolberg Environmental Health Program Manager 2101 W. Pine St., Sandpoint, ID 83864 Office: 208-265-6384 Office Desk: 208-920-7902 Email: kkolberg@phd1.idaho.gov Web: Panhandlehealthdistrict.org
---	--

IMPORTANT: The information contained in this email may be privileged, confidential or otherwise protected from disclosure. All persons are advised that they may face penalties under state and federal law for sharing this information with unauthorized individuals. If you received this email in error, please reply to the sender that you received this information in error. Also, please delete this email after replying to the sender.

3 attachments

 **Notice of Public Hearing_ZoningCommission 06.26.25 (1).pdf**
616K

 **Deerfield Subdivision PHD Letter 5.2.2025.pdf**
793K

 **Deerfield Plat - PHD Comments 6.18.25.pdf**
1023K

NOTICE OF PUBLIC HEARING



I hereby certify that a true and correct copy of this "Notice of Public Hearing" was digitally transmitted or mailed (postage prepaid) on this **27th** day of **May 2025**.

Janna Brown

Janna Brown, Administrative Assistant III

This notice was mailed to political subdivisions, property owners within 300 feet of the subject property, and the media on **Tuesday, May 27, 2025**.

NOTICE IS HEREBY GIVEN that the Bonner County Zoning Commission will hold a public hearing at **5:30 pm on Thursday, June 26, 2025**, in the Bonner County Administration Building, 1500 Highway 2, Sandpoint, Idaho, by Zoom teleconference, and YouTube Livestream to consider the following request:

File S0001-25 - Long Plat - Deerfield

The applicant is requesting to subdivide and plat an approximately 32.67-acre parcel into twenty-four (24) residential lots ranging from approximately one (1) to three (3) acres each and one stormwater tract. The property is zoned Suburban. The subject property is located off Baldy Mountain Rd in Section 16, Township 57 North, Range 2 West, Boise Meridian, Bonner County Idaho. This project is located in the Syringa Heights Water District and Northside Fire District service areas, and the Area of Impact for the City of Sandpoint.

For details regarding this application, Zoom teleconference, or YouTube livestream, visit the Planning Department web site at www.bonnercountyid.gov/departments/Planning. Staff reports are available online or may be viewed at the planning department approximately a week before the scheduled hearing.

Written statements must be submitted to the planning department record no later than seven (7) days prior to the public hearing. Written statements not exceeding one standard letter sized, single spaced page may be submitted at the public hearing. Statements can be sent to the Bonner County Planning Department at 1500 Highway 2, Suite 208, Sandpoint, Idaho 83864; faxed to 866-537-4935 or e-mailed to planning@bonnercountyid.gov. The referenced start time stated above reflects the beginning of the hearing. Specific file start time and hearing duration vary.

During the hearing for this application, the public will be given an opportunity to provide testimony and/or evidence regarding how the proposal does or does not comply with the applicable approval criteria of the Bonner County Revised Code. At the close of the public hearing, the governing board will make a decision on the application that may include, but is not limited to, approval, denial, remand, or continuance of the public hearing. Any person needing special accommodations to participate in the public hearing should contact the Bonner County Planning Department at (208) 265-1458 at least 48 hours prior to the scheduled hearing.

If you have no comment or response, you may indicate below and return this form to the Planning Department.

NO COMMENT _____
Name

Date

**SITUATE IN THE E1/2 OF THE SW1/4 OF SECTION 16
TOWNSHIP 57 NORTH, RANGE 2 WEST, BOISE MERIDIAN
BONNER COUNTY, IDAHO**

[illegible]

THIS PLAT WAS ESTABLISHED BY GPS CONTROL. COORDINATES DERIVED FROM NGS OPUS SOLUTIONS USING A REFERENCE FRAME OF NAD83 (2011 EPOCH: 2010.000). ALL BEARINGS REFER TO THE IGA-HO COORDINATE SYSTEM OF 1983, WEST ZONE, (1983) US SURVEY FT. REFER TO THE DRAWING FOR SPECIFIC LINE AND MONUMENTS USED. DISTANCES SHOWN HAVE BEEN CONVERTED FROM GRID TO GROUND USING A COMBINED ADJUSTMENT FACTOR (CAFI) OF 1.003159221.

[illegible]

(R1) GUST BANGS DEAD INSTRUMENT No. 476237 RECORDED 2017 2021
(R2) GUST BANGS DEAD INSTRUMENT No. 476237 RECORDED 2017 2021
(R3) RECORD OF SURVEY INSTRUMENT No. 22010 IN BOOK 1 OF PLATS AT PAGE 152
(R4) RECORD OF SURVEY INSTRUMENT No. 942527 RECORDED BY MARJORIE DEER, PL 95 9615, 1998
(R5) RECORD OF SURVEY INSTRUMENT No. 567386 RECORDED BY GEORGE WASHALL, PL 5 2946, 2000
(R6) RECORD OF SURVEY INSTRUMENT No. 567395 RECORDED BY GEORGE WASHALL, PL 5 2946, 2000
(R7) RECORD OF SURVEY INSTRUMENT No. 361244 RECORDED BY DAVID S. BROWN, PL 5 5050, 1998
(R8) RECORD OF SURVEY INSTRUMENT No. 247434 RECORDED BY ROBERT WARD, PL 5 8182, 1998

[illegible]


HMH
engineering 476864 Highway 95, Suite 3
Ponderay, ID 83852
(208) 635-5825

SITUATE IN THE E1/2 OF THE SW1/4 OF SECTION 16
TOWNSHIP 57 NORTH, RANGE 2 WEST, BOISE MERIDIAN
BONNER COUNTY, IDAHO

	FOUND ALUMINUM CAP/NO TIE/MS, AS DESCRIBED
	FOUND SIP REBAR, AS DESCRIBED
	FOUND 10# W/PL, AS DESCRIBED
	FOUND 10# REBAR, AS DESCRIBED
	SET 10# SIP REBAR WITH YELLOW PLASTIC CAP STAMPED "NULCDS P.3.3088"
	SET 10# SIP REBAR WITH YELLOW PLASTIC CAP STAMPED "NULCDS P.3.3088" OR AS DESCRIBED
	SET 10# SIP REBAR WITH YELLOW PLASTIC CAP STAMPED "NULCDS P.3.3088"
	SET ALUMINUM CAP ON SIP/MS REBAR
	CALCULATED POINT, NOTHING FOUND OR SET
	SUBJECT PROPERTY BOUNDARY
	INTERIOR LOT/COOK LINES
	ADJACENT PROPERTY BOUNDARY
	SECTION LINE (BLM SOLUTION)
	SECTION LINE (RSJ SOLUTION)
	EAST/WEST LINE
	RIGHT OF WAY LINE
	ROAD CENTERLINE
	COLONNATED/RETAINING BOUNDARY LINE

Line Table		
Line #	Length	Direction
L1	232.20	S89°04'33"E
L2	232.21	S89°04'33"E
L3	40.44	S07°59'06"E
L4	23.58	N07°44'28"E
L5	17.07	S89°04'33"E
L6	22.71	S49°58'51"E
L7	18.12	S68°38'03"E
L8	45.00	N59°03'40"E

Curve #	Length	Radius	Delta	Chord	Chord Bearing
C1	57.68	50.00	68°09'58"	54.54	S56°28'13"W
C2	78.94	50.00	90°02'00"	70.71	N45°28'50"E
C3	23.07	20.00	66°05'36"	21.81	N56°29'10"W
C4	31.42	20.00	90°02'00"	28.28	S45°28'50"E
C5	125.66	50.00	90°02'00"	113.14	N45°28'50"E
C6	31.61	20.00	90°02'44"	28.42	N45°40'15"E
C7	31.23	20.00	66°07'18"	28.15	S44°16'48"E
C8	47.36	30.00	90°07'30"	42.60	S43°42'55"E
C9	14.57	20.00	41°44'10"	14.25	N68°33'10"E
C10	8.50	16.69	247°12'36"	8.44	N33°55'37"E
C11	46.88	50.00	68°09'58"	42.28	S44°27'54"E



DN-02401

PAGE 3 OF 3

HMH
engineering

47664 Highway 95, Suite 3
Ponderay, ID 83852
(208) 635-5825

[illegible]



Panhandle Health District

Healthy People in Healthy Communities

Public Health
Prevent. Promote. Protect.

Panhandle Health District

June 18, 2025

Bonner County Planning Dept.

1500 Highway 2, Suite 208

Sandpoint, ID 83864

Re: File S0001-25 – Long Plat – Deerfield

Dear Bonner County Planning -

This letter is intended as follow-up comments to the attached letter/comments Panhandle Health District (PHD) sent on May 2, 2025. As of today's date, PHD does not have adequate information to verify whether sanitary restrictions may be lifted on all 24 proposed 'buildable' lots associated with this plat.

While the soils and overall site conditions were found to be generally adequate for complex alternative septic systems (per PHD Preliminary Soil Analysis dated 11/27/24), PHD must receive a detailed site plan indicating all proposed septic system locations and distances to all features of concern; including all temporary, intermittent and permanent surface water (existing & proposed, and both man-made and naturally existing).

The applicant must demonstrate that the sanitary services proposed for each lot will fit within the property lines as proposed, or within dedicated legal easements on neighboring parcels. Any depressions or drainages that hold surface water for 2 months or more require the setback for intermittent or permanent surface water, and this applies to both man-made or natural depressions that hold water. The Idaho Subsurface Sewage Disposal Rules IDAPA 58.01.03.003.39 define surface water as: *Surface Water - Intermittent, Permanent, Temporary. a. Any waters of the State which flow or are contained in natural or man-made depressions in the earth's surface. This includes, but is not limited to, lakes, streams, canals, and ditches. b. An intermittent surface water exists continuously for a period of more than two (2) months but not more than six (6) months a year. c. A permanent surface water exists continuously for a period of more than six (6) months a year. d. A temporary surface water exists continuously for a period of less than two (2) months a year.*

Each proposed 'buildable' lot must be verified to have adequate space for both a Primary & Replacement Septic system. It is important to note that the site has clay soils, which means the septic systems will be very large. For example, if someone wants one dwelling with 4 bedrooms (300gpd), they would need 1,500sqft of area for their primary drainfield, and another 1500sqft for their future replacement field, for a total of 3,000sqft. All lots will require extremely careful planning to ensure setbacks can be met to all waterlines, all surface water, property lines, dwellings, etc.

PHD has requested a detailed site plan from the project engineer so we can verify the details of the proposed sanitary services in relation to the rest of the project plans. PHD may need to conduct additional field work to verify the proposed septic locations will be adequate and compliant with IDAPA 58.01.03. PHD also needs all necessary reviews and approvals for the proposed water system infrastructure.

If you have any questions regarding this information, please contact our office or email me at kkolberg@phd1.idaho.gov.

Regards,

Kathryn Kolberg, Environmental Health Program Manager

Sandpoint – Bonner County
2101 W. Pine St.
Sandpoint, ID 83864
208.263.5159



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] File S0001-25 - Long Plat - Deerfield

1 message

Kathryn Kolberg <KKolberg@phd1.idaho.gov>

Wed, Jun 18, 2025 at 3:36 PM

To: Bonner Planning <planning@bonnercountyid.gov>

Cc: Amanda Cerise <acerise@phd1.idaho.gov>, CRO Plan Submittal <CROPlanSubmittal@deq.idaho.gov>

Hi –

Please see attached for PHD comments dated 6.18.25 and 5.2.25 regarding the proposed Deerfield plat and upcoming Zoning Commission Hearing.

Regards,
Kathryn

 Public Health Prevent. Promote. Protect. Panhandle Health District	Kathryn Kolberg Environmental Health Program Manager 2101 W. Pine St., Sandpoint, ID 83864 Office: 208-265-6384 Office Desk: 208-920-7902 Email: kkolberg@phd1.idaho.gov Web: Panhandlehealthdistrict.org
--	--

IMPORTANT: The information contained in this email may be privileged, confidential or otherwise protected from disclosure. All persons are advised that they may face penalties under state and federal law for sharing this information with unauthorized individuals. If you received this email in error, please reply to the sender that you received this information in error. Also, please delete this email after replying to the sender.

3 attachments **Notice of Public Hearing_ZoningCommission 06.26.25 (1).pdf**
616K **Deerfield Subdivision PHD Letter 5.2.2025.pdf**
793K **Deerfield Plat - PHD Comments 6.18.25.pdf**
1023K

NOTICE OF PUBLIC HEARING



I hereby certify that a true and correct copy of this "Notice of Public Hearing" was digitally transmitted or mailed (postage prepaid) on this **27th** day of **May 2025**.

Janna Brown

Janna Brown, Administrative Assistant III

This notice was mailed to political subdivisions, property owners within 300 feet of the subject property, and the media on **Tuesday, May 27, 2025**.

NOTICE IS HEREBY GIVEN that the Bonner County Zoning Commission will hold a public hearing at **5:30 pm on Thursday, June 26, 2025**, in the Bonner County Administration Building, 1500 Highway 2, Sandpoint, Idaho, by Zoom teleconference, and YouTube Livestream to consider the following request:

File S0001-25 - Long Plat - Deerfield

The applicant is requesting to subdivide and plat an approximately 32.67-acre parcel into twenty-four (24) residential lots ranging from approximately one (1) to three (3) acres each and one stormwater tract. The property is zoned Suburban. The subject property is located off Baldy Mountain Rd in Section 16, Township 57 North, Range 2 West, Boise Meridian, Bonner County Idaho. This project is located in the Syringa Heights Water District and Northside Fire District service areas, and the Area of Impact for the City of Sandpoint.

For details regarding this application, Zoom teleconference, or YouTube livestream, visit the Planning Department web site at www.bonnercountyid.gov/departments/Planning. Staff reports are available online or may be viewed at the planning department approximately a week before the scheduled hearing.

Written statements must be submitted to the planning department record no later than seven (7) days prior to the public hearing. Written statements not exceeding one standard letter sized, single spaced page may be submitted at the public hearing. Statements can be sent to the Bonner County Planning Department at 1500 Highway 2, Suite 208, Sandpoint, Idaho 83864; faxed to 866-537-4935 or e-mailed to planning@bonnercountyid.gov. The referenced start time stated above reflects the beginning of the hearing. Specific file start time and hearing duration vary.

During the hearing for this application, the public will be given an opportunity to provide testimony and/or evidence regarding how the proposal does or does not comply with the applicable approval criteria of the Bonner County Revised Code. At the close of the public hearing, the governing board will make a decision on the application that may include, but is not limited to, approval, denial, remand, or continuance of the public hearing. Any person needing special accommodations to participate in the public hearing should contact the Bonner County Planning Department at (208) 265-1458 at least 48 hours prior to the scheduled hearing.

If you have no comment or response, you may indicate below and return this form to the Planning Department.

NO COMMENT _____
Name

Date



Panhandle Health District

Healthy People in Healthy Communities

Public Health
Prevent. Promote. Protect.

Panhandle Health District

June 18, 2025

Bonner County Planning Dept.

1500 Highway 2, Suite 208

Sandpoint, ID 83864

Re: File S0001-25 – Long Plat – Deerfield

Dear Bonner County Planning -

This letter is intended as follow-up comments to the attached letter/comments Panhandle Health District (PHD) sent on May 2, 2025. As of today's date, PHD does not have adequate information to verify whether sanitary restrictions may be lifted on all 24 proposed 'buildable' lots associated with this plat.

While the soils and overall site conditions were found to be generally adequate for complex alternative septic systems (per PHD Preliminary Soil Analysis dated 11/27/24), PHD must receive a detailed site plan indicating all proposed septic system locations and distances to all features of concern; including all temporary, intermittent and permanent surface water (existing & proposed, and both man-made and naturally existing).

The applicant must demonstrate that the sanitary services proposed for each lot will fit within the property lines as proposed, or within dedicated legal easements on neighboring parcels. Any depressions or drainages that hold surface water for 2 months or more require the setback for intermittent or permanent surface water, and this applies to both man-made or natural depressions that hold water. The Idaho Subsurface Sewage Disposal Rules IDAPA 58.01.03.003.39 define surface water as: *Surface Water - Intermittent, Permanent, Temporary. a. Any waters of the State which flow or are contained in natural or man-made depressions in the earth's surface. This includes, but is not limited to, lakes, streams, canals, and ditches. b. An intermittent surface water exists continuously for a period of more than two (2) months but not more than six (6) months a year. c. A permanent surface water exists continuously for a period of more than six (6) months a year. d. A temporary surface water exists continuously for a period of less than two (2) months a year.*

Each proposed 'buildable' lot must be verified to have adequate space for both a Primary & Replacement Septic system. It is important to note that the site has clay soils, which means the septic systems will be very large. For example, if someone wants one dwelling with 4 bedrooms (300gpd), they would need 1,500sqft of area for their primary drainfield, and another 1500sqft for their future replacement field, for a total of 3,000sqft. All lots will require extremely careful planning to ensure setbacks can be met to all waterlines, all surface water, property lines, dwellings, etc.

PHD has requested a detailed site plan from the project engineer so we can verify the details of the proposed sanitary services in relation to the rest of the project plans. PHD may need to conduct additional field work to verify the proposed septic locations will be adequate and compliant with IDAPA 58.01.03. PHD also needs all necessary reviews and approvals for the proposed water system infrastructure.

If you have any questions regarding this information, please contact our office or email me at kkolberg@phd1.idaho.gov.

Regards,

Kathryn Kolberg, Environmental Health Program Manager

Sandpoint – Bonner County
2101 W. Pine St.
Sandpoint, ID 83864
208.263.5159



Jason Johnson <jason.johnson@bonnercountyid.gov>

Fwd: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

1 message

Janna Brown <janna.brown@bonnercountyid.gov>
To: Jason Johnson <jason.johnson@bonnercountyid.gov>

Tue, Jun 3, 2025 at 1:25 PM

**Thank you,
Janna Brown, Administrative Assistant III
Bonner County Planning Department
208-265-1458 ext - 1252**

----- Forwarded message -----

From: **Matt Mulder** <matt.mulder@bonnercountyid.gov>
Date: Tue, Jun 3, 2025 at 1:08 PM
Subject: Fwd: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield
To: Mail-Planning <planning@bonnercountyid.gov>
Cc: Jason Topp <jason.topp@bonnercountyid.gov>, Dan Tadic <dtadic@hmh-llc.com>

Planning,
The Bonner County Road & Bridge Department has the following comments regarding the Deerfield Subdivision:

1. The Applicant's Engineer has been coordinating the roadway designs and dedication of additional public right of way with the R&B Dept since early in the project development, and as a result there are few comments needed regarding the roadway plans. The roads as designed meet or exceed the standard requirements for a privately maintained public road, Local Access Road A, with more than 200 ADT (Average Daily Traffic) and are approved for construction as presented.
2. After reviewing the Trip Generation & Distribution Letter, it is my opinion that no additional traffic impact study is required. Baldy Mountain Rd is a County maintained road with hard surfacing and a 35mph speed limit and is more than capable of supporting the increased traffic loads generated by the subdivision. The speeds, sight distances, and traffic volumes do not warrant turn lanes.
3. A road approach encroachment permit will need to be applied for in order to construct the new connection to Baldy Mountain Road. As driveways are added later, residential encroachment permits for each new driveway will be required. Corner lots will be required to access off of Deerfield Drive.
4. There is a note regarding maintenance of the roads in the Owners Certificate as being by the HOA per CC&R's. Add additional language making it clear that "the roads being constructed do not meet the standards for County maintenance and will be ineligible for future consideration of County maintenance."

-Matt Mulder, PE
Staff Engineer
Bonner County Road & Bridge
208-255-5681 ext 1

----- Forwarded message -----

From: **Bonner County Planning** <planning@bonnercountyid.gov>
Date: Wed, May 28, 2025 at 11:51 AM
Subject: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield
To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>, Amber Burgess <clerk@ebsewerdistrict.com>, Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>, Avista Copr - Jay West <jay.west@avistacorp.com>, Avista Corp - Peggy George <peggy.george@avistacorp.com>, Becky Meyer <becky.meyer@lposd.org>, Bill Berg <billb@bbsewer.org>, Bonner County Assessors <assessorsgroup@bonnercountyid.gov>, BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>, Brenna Garro <Brenna.Garro@oer.idaho.gov>, Bryan Quayle <quaylelanduseconsulting@gmail.com>, Chace Bell <chace.bell@idwr.idaho.gov>, Chief Debbie Carpenter <chief@spiritlakefire.com>, City of Clark Fork <city@clarkforkidaho.org>, City of Dover <cityclerk@cityofdoveridaho.org>, City of East Hope Franck <easthope.city@gmail.com>, City of Hope <hopecityclerk@gmail.com>, City of Oldtown <cityofoldtown@hotmail.com>, City of Priest River <layers@priestriver-id.gov>, City of Sandpoint Planning <cityplanning@sandpointidaho.gov>, cityclerk@spiritlakeid.gov <cityclerk@spiritlakeid.gov>, Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>, Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>, Craig Hill <craighill@hillsresort.com>, D1Permits <D1Permits@itd.idaho.gov>, Dan Brown <dbrown@idl.idaho.gov>, Dan McCracken <Dan.McCracken@deq.idaho.gov>, Dan Scholz <dan.scholz@nli.coop>, Dean Davis <deandavis@sd83.org>, DEQ - Kristie McEnroe <kristie.mcenroe@deq.idaho.gov>, East Bonner Library <Amanda@ebonnerlibrary.org>, East Priest Lake Fire District <eastpriestlakefd@gmail.com>, Erik Sjoquist <esjoquist@idl.idaho.gov>, Federal Aviation Administration <Heather.pate@faa.gov>, Frankie Dunn <Frankiejdunn@hotmail.com>, Fritz Broschet <outletbaysewer@gmail.com>, Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>, Gavin Gilcrease <ggilcrease@sandpointidaho.gov>, Horsmon, Merritt <merritt.horsmon@idfg.idaho.gov>, ID State Historical Society - Dan Everhart <dan.everhart@ishs.idaho.gov>, Idaho Department of Environmental Quality <deqcomments@deq.idaho.gov>, Independent Hwy Dist - Julie Bishop <ihndclerk@gmail.com>, ITD - Robert Beachler <robert.beachler@itd.idaho.gov>, ITD - Stacy Simkins <stacy.simkins@itd.idaho.gov>, Jack Schenck <Jack.schenck@vyvebb.com>, Jamie Brown <jamieb@iniandpower.com>, Janice Best <janicesb@televar.com>, Jason Johnson <jason.johnson@bonnercountyid.gov>, Jason Kimberling <jason.kimberling@itd.idaho.gov>, Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>, Jessie Roe <BWSD637@gmail.com>, Joe Kren <joekren@sd83.org>, Jordan Brooks <coolinsewer@gmail.com>, KayLeigh Miller <klmiller@ponderay.org>, kbsd sewer <kbsdpl@hotmail.com>, Ken Flint <ken_flint@tcenergy.com>, Kenny Huston <kenny.huston@oer.idaho.gov>, Kim Hoodenpyle <kjh5345@gmail.com>, Kim Spacek <kimspacek@sd83.org>, Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>, Laclede Water District <linfo@lacledewaterdistrict.org>, Lakeland Joint School District #272 <cpursley@lakeland272.org>, Lisa Rosa <hr@ebonnerlibrary.org>, Matt Diel <matt.diel@lposd.org>, Midas Water <midaswatercorp@gmail.com>, Mike Ahmer <mahmer@idl.idaho.gov>, Mike Schacht <firedept@clarkforkidaho.org>, Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>, Navy - Glynis Casey <glynis.casey@navy.mil>, North of the Narrows Fire District <Huckbay2501@gmail.com>, Northern Lights <kristin.mettke@nli.coop>, Northern Lights - Clint Brewing <clint.brewington@nli.coop>, Northside Water and Syringa Heights Water Association <allwater49@outlook.com>, Oden Water Association - Carla Poelstra <odenwater@gmail.com>, Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>, PHD <EHapplications@phd1.idaho.gov>, Priest Lake Public Library District <plplibrary@hotmail.com>, Richard Hash <Rich.hash2022@gmail.com>, Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>, Ryan Zandhuisen <rzanhuisen@idl.idaho.gov>, Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>, Sagle Valley Water & Sewer District <markc@smartplugs.com>, Sam Owen Fire Rescue Sam Owen Fire Rescue <sofd@wow-tel.net>, Sam Ross <sam.ross@nli.coop>, sandpointairport@gmail.com <sandpointairport@gmail.com>, Sarah Gilmore <sgilmore@sandpointidaho.gov>, School District 84 Transportation - James Koehler <james.koehler@lposd.org>, SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>, Selkirk Association of Realtors <danielle@selkirkaoar.com>, Selkirk Recreation District <elgar@whoi.edu>, Sheryl Austin <granitereeder@gmail.com>, SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>, Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>, Steve Elgar <selgar@mac.com>, Superintendent School Dist 84 <kelly.fisher@lposd.org>, Symone.legg@itd.idaho.gov <Symone.legg@itd.idaho.gov>, TC Energy / TransCanada <US_crossings@tcenergy.com>, Teresa Decker <Huckleberryhoa@gmail.com>, Teresa Decker <huckbayutilities01@gmail.com>, Teresa Zamora <utilities@stoneridgeidaho.com>, Theresa Wheat <theresa@kootenai.org>, Tim Ventress <chventresswplvfd@hotmail.com>, Timberlake Fire

6/3/25, 1:37 PM

Bonner County Mail - Fwd: Bonner County Planning - S0001-25 Agency Review - Long Plat - Deerfield

District <Kwright@timberlakefire.com>, Tom Renzi <epifdchief@gmail.com>, US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>, West Bonner Library <meagan@westbonnerlibrary.org>, West Pend Oreille Fire District <wpofd1@gmail.com>
Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>, Jessica Montgomery <jessica.montgomery@bonnercountyid.gov>

The above-named application has been submitted to the Bonner County Planning Department for processing.

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

**Thank you,
Janna Brown, Administrative Assistant III
Bonner County Planning Department
208-265-1458 ext - 1252**



Notice of Public Hearing_ZoningCommission 06.26.25.pdf

616K



Janna Brown <janna.brown@bonnercountyid.gov>

[EXT SENDER] Public Hearing Statement Submission - File S00001-25-Long Plat - Deerfield

1 message

Tammy Miller <tmiller@selkirkfire.us>

Tue, Jun 3, 2025 at 1:15 PM

To: Bonner County Planning <planning@bonnercountyid.gov>

Cc: Jeff Armstrong <jarmstrong@selkirkfire.us>

Please accept this submission from Northside Fire Chief, Jeff Armstrong, regarding the public hearing, File S00001-25-Long Plat-Deerfield.

A response to confirm receipt of the attached would be appreciated.

Thank you,



Tammy Miller, Fire Administrator

SELKIRK FIRE RESCUE, & EMS

P.O. Box 760
2689 Gun Club Road
Sagle, ID 83860
(208) 263-7929
www.selkirkfire.us

**Public Hearing Response - File S0001-25 (Deerfield Subdivision).pdf**

1393K

NOTICE OF PUBLIC HEARING



I hereby certify that a true and correct copy of this "Notice of Public Hearing" was digitally transmitted or mailed (postage prepaid) on this **27th** day of **May 2025**.

Janna Brown

Janna Brown, Administrative Assistant III

This notice was mailed to political subdivisions, property owners within 300 feet of the subject property, and the media on **Tuesday, May 27, 2025**.

NOTICE IS HEREBY GIVEN that the Bonner County Zoning Commission will hold a public hearing at **5:30 pm on Thursday, June 26, 2025**, in the Bonner County Administration Building, 1500 Highway 2, Sandpoint, Idaho, by Zoom teleconference, and YouTube Livestream to consider the following request:

File S0001-25 - Long Plat - Deerfield

The applicant is requesting to subdivide and plat an approximately 32.67-acre parcel into twenty-four (24) residential lots ranging from approximately one (1) to three (3) acres each and one stormwater tract. The property is zoned Suburban. The subject property is located off Baldy Mountain Rd in Section 16, Township 57 North, Range 2 West, Boise Meridian, Bonner County Idaho. This project is located in the Syringa Heights Water District and Northside Fire District service areas, and the Area of Impact for the City of Sandpoint.

For details regarding this application, Zoom teleconference, or YouTube livestream, visit the Planning Department web site at www.bonnercountyid.gov/departments/Planning. Staff reports are available online or may be viewed at the planning department approximately a week before the scheduled hearing.

Written statements must be submitted to the planning department record no later than seven (7) days prior to the public hearing. Written statements not exceeding one standard letter sized, single spaced page may be submitted at the public hearing. Statements can be sent to the Bonner County Planning Department at 1500 Highway 2, Suite 208, Sandpoint, Idaho 83864; faxed to 866-537-4935 or e-mailed to planning@bonnercountyid.gov. The referenced start time stated above reflects the beginning of the hearing. Specific file start time and hearing duration vary.

During the hearing for this application, the public will be given an opportunity to provide testimony and/or evidence regarding how the proposal does or does not comply with the applicable approval criteria of the Bonner County Revised Code. At the close of the public hearing, the governing board will make a decision on the application that may include, but is not limited to, approval, denial, remand, or continuance of the public hearing. Any person needing special accommodations to participate in the public hearing should contact the Bonner County Planning Department at (208) 265-1458 at least 48 hours prior to the scheduled hearing.

If you have no comment or response, you may indicate below and return this form to the Planning Department.


NO COMMENT _____

Name

Date

SEE ATTACHMENT 6/3/25

[Signature]





NORTHSIDE FIRE DISTRICT

P.O. Box 181
Ponderay, Idaho 83852
Phone: 208-265-4114

June 3, 2025

Bonner County Planning Department

RE: Public Hearing – File S0001-25
Deerfield Subdivision, RP57N02W164952A

To Whom It May Concern:


The Northside Fire District is aware of the Deerfield subdivision and plans for development off Baldy Mountain Rd. For the last few months, the developer and his representatives have been working with fire district staff on meeting all the requirements of the District as well as the International Fire Code (IFC). They have been very communicative and great to work with.

We worked with them to meet the intent of the IFC regarding fire flow and water storage. We reached an agreement, and I provided an IFC variance, that will allow for a single large tank for water storage; an option that will allow for easier access to water in the event of an incident in or around the community.

We continue to be concerned about the amount of development in Bonner County, while at the same time not addressing infrastructure. It must be noted that we do not not have the adequate fire resources to protect this subdivision, or other areas of the County, from a major fire event. Knowing that, the voters recently spoke and decided they did not support enhanced fire protection. With that in mind we respectfully ask the County to proceed cautiously into the future and consider methods that will allow for responsible growth in the wildland urban interface.

Should you have any questions, please feel free to reach out.

Sincerely,



Jeff Armstrong, Fire Chief

cc. file, Board of Commissioners



Dylan Young <dylan.young@bonnercountyid.gov>

Bonner County Planning - File S0001-25 Agency Review

Bonner County Planning Department <planning@bonnercountyid.gov>

Tue, Jul 29, 2025 at 8:41 AM

To: Alan Brinkmeier <alan.brinkmeier@bonnercountyid.gov>, Amber Burgess <clerk@ebsewerdistrict.com>, Army Corps of Engineers <CENWW-RD-CDA@usace.army.mil>, Avista Copr - Jay West <jay.west@avistacorp.com>, Avista Corp - Peggy George <peggy.george@avistacorp.com>, Becky Meyer <becky.meyer@lposd.org>, Bill Berg <billb@bbsewer.org>, Bonner County Assessors <assessorsgroup@bonnercountyid.gov>, BONNER COUNTY HISTORICAL SOCIETY AND MUSEUM <DIRECTOR@bonnercountyhistory.org>, Brenna Garro <Brenna.Garro@oer.idaho.gov>, Bryan Quayle <quaylelanduseconsulting@gmail.com>, Chace Bell <chace.bell@idwr.idaho.gov>, Chief Debbie Carpenter <chief@spirittlakefire.com>, City of Clark Fork <city@clarkforkidaho.org>, City of Dover <cityclerk@cityofdoveridaho.org>, City of East Hope Franck <easthope.city@gmail.com>, City of Hope <hopecityclerk@gmail.com>, City of Kootenai <cityclerk@cityofkootenai.org>, City of Oldtown <cityofoldtown@hotmail.com>, City of Priest River <layers@priestriver-id.gov>, City of Sandpoint Planning <cityplanning@sandpointidaho.gov>, "cityclerk@spirittlakeid.gov" <cityclerk@spirittlakeid.gov>, Colleen Johnson <CJohnson@kootenaiponderaysewerdistrict.org>, Coolin-Cavanaugh Bay Fire Protection District <coolinfirechief@gmail.com>, Craig Hill <craighill@hillsresort.com>, D1Permits <D1Permits@itd.idaho.gov>, Dan Brown <dbrown@idl.idaho.gov>, Dan McCracken <Dan.McCracken@deq.idaho.gov>, Dan Scholz <dan.scholz@nli.coop>, Dave Schuck <dave.schuck@bonnercountyid.gov>, Dean Davis <deandavis@sd83.org>, DEQ - Kristie McEnroe <kristie.mcenroe@deq.idaho.gov>, East Bonner Library <Amanda@ebonnerlibrary.org>, East Priest Lake Fire District <eastpriestlakefd@gmail.com>, Erik Sjoquist <esjoquist@idl.idaho.gov>, Federal Aviation Administration <Heather.pate@faa.gov>, Frankie Dunn <Frankiejduhn@hotmail.com>, Fritz Broschet <outletbaysewer@gmail.com>, Garfield Bay Water and Sewer District Clerk <garfieldbaywsd@hotmail.com>, Gavin Gilcrease <ggilcrease@sandpointidaho.gov>, ID State Historical Society - Dan Everhart <dan.everhart@ishs.idaho.gov>, Idaho Department of Environmental Quality <deqcomments@deq.idaho.gov>, Independent Hwy Dist - Julie Bishop <ihdclerk@gmail.com>, ITD - Robert Beachler <robert.beachler@itd.idaho.gov>, ITD - Stacy Simkins <stacy.simkins@itd.idaho.gov>, Jack Schenck <Jack.schenck@vyvebb.com>, Jamie Brown <jamieb@inlandpower.com>, Janice Best <janicesb@televar.com>, Jason Johnson <jason.johnson@bonnercountyid.gov>, Jason Kimberling <jason.kimberling@itd.idaho.gov>, Jeff Lindsey <jeff.lindsey@bonnercountyid.gov>, Jessie Roe <BWSD637@gmail.com>, Joe Kren <joe@sd83.org>, Jordan Brooks <coolinsewer@gmail.com>, Karen Quenell <kquenell@northsidefire.org>, Kayleigh Miller <klmiller@ponderay.org>, kbsd sewer <kbsdpl@hotmail.com>, Ken Flint <ken_flint@tcenergy.com>, Kenny Huston <kenny.huston@oer.idaho.gov>, Kim Hoodenpyle <kjh5345@gmail.com>, Kim Spacek <kimspacek@sd83.org>, Kimberly Hobson <Kimberly.Hobson@itd.idaho.gov>, Laclede Water District <info@lacledewaterdistrict.org>, Lakeland Joint School District #272 <cpursley@lakeland272.org>, Lisa Rosa <hr@ebonnerlibrary.org>, Matt Diel <matt.diel@lposd.org>, Merritt Horsmon <merritt.horsmon@idfg.idaho.gov>, Midas Water <midaswatercorp@gmail.com>, Mike Ahmer <mahmer@idl.idaho.gov>, Mike Schacht <firedept@clarkforkidaho.org>, Natural Resource Conservation Service - Greg Becker <greg.becker@id.usda.gov>, Navy - Glynis Casey <glynis.casey@navy.mil>, North of the Narrows Fire District <Huckbay2501@gmail.com>, Northern Lights <kristin.mettke@nli.coop>, Northern Lights - Clint Brewing <clint.brewington@nli.coop>, Northside Water and Syringa Heights Water Association <allwater49@outlook.com>, Oden Water Association - Carla Poelstra <odenwater@gmail.com>, Pend Oreille Hospital District <kim.kichenmaster@bonnergeneral.org>, PHD <EHApplications@phd1.idaho.gov>, Priest Lake Public Library District <plplibrary@hotmail.com>, Richard Hash <Rich.hash2022@gmail.com>, Road & Bridge - Matt Mulder <matt.mulder@bonnercountyid.gov>, Ryan Zandhuisen <rzanhuisen@idl.idaho.gov>, Sagle Valley Water & Sewer District <markc@smartplugs.com>, Sagle Valley Water and Sewer District <saglewatersewer@gmail.com>, Sam Owen Fire Rescue <sofd@wow-tel.net>, Sam Ross <sam.ross@nli.coop>, Sarah Gilmore <sgilmore@sandpointidaho.gov>, School District 84 Transportation - James Koehler <james.koehler@lposd.org>, SCHWEITZER FIRE DISTRICT <SchweitzerFireDistrict@gmail.com>, Selkirk Association of Realtors <danielle@selkirkaor.com>, Selkirk Recreation District <elgar@whoi.edu>, Sheryl Austin <granitereeder@gmail.com>, SOURDOUGH POINT OWNERS ASSOCIATION <sourdoughpoint@hotmail.com>, Southside Water and Sewer <southsidewaterandsewer@swsdidaho.org>, Steve Elgar <selgar@mac.com>, Superintendent School Dist 84 <kelly.fisher@lposd.org>, "Symone.legg@itd.idaho.gov" <Symone.legg@itd.idaho.gov>, TC Energy / TransCanada <US_crossings@tcenergy.com>, Teresa Decker <Huckleberryhoa@gmail.com>, Teresa Decker <huckbayutilities01@gmail.com>, Teresa Zamora <utilities@stoneridgeidaho.com>, Theresa Wheat <theresa@kootenai.org>, Tim Ventress <chventresswplvfd@hotmail.com>, Timberlake Fire District <Kwright@timberlakefire.com>, Tom Renzi <epfldchief@gmail.com>, US Fish & Wildlife Services <fw1idahoconsultationrequests@fws.gov>, West Bonner Library <meagan@westbonnerlibrary.org>, West Pend Oreille Fire District <wpofd1@gmail.com>
Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>, Jeannie Welter <jeannie.welter@bonnercountyid.gov>

Please review the application relative to your agency's area of expertise and include any recommended conditions of approval and supporting code sections. Please see attached for details.

Dylan Young
Bonner County Planning Department
Hearing Coordinator
208-265-1458

Now Live: Apply for Your Building Location Permit Online!

We're making building easier! You can now apply for your **Building Location Permit** quickly and securely through our **new citizen online portal**, available 24/7 from the comfort of your home or office. You can also apply on one of the kiosks provided in the Planning Department office, located in the County Administrative Building, Suite 208.

Fast & easy application process
Track your permit status in real time
Upload documents directly

Online Application Guide

Visit <https://bonnercountyid-energovweb.tylerhost.net/apps/selfservice#/home> **to get started today!**

Effective July 1, 2025, all Building Location Permits must be applied for through the online citizen portal and we will no longer be accepting applications sent via email or printed paper applications. Have questions? Call 208-265-1458, our team is ready to help.

Build smarter. Apply online.



Notice of Public Hearing_BOCC08.14.25.pdf
627K



Jason Johnson <jason.johnson@bonnercountyid.gov>

Re: [EXT SENDER] RE: Deerfield Subdivision - S0001-25

1 message

Jake Gabell <jake.gabell@bonnercountyid.gov>

Tue, May 13, 2025 at 12:30 PM

To: Bill Dean <bdean@sandpointidaho.gov>

Cc: Jason Welker <jwelker@sandpointidaho.gov>, Alexander Feyen <alexander.feyen@bonnercountyid.gov>, Janna Brown <janna.berard@bonnercountyid.gov>, Jason Johnson <jason.johnson@bonnercountyid.gov>

Hey Bill,

I don't believe we need anything else from you at this time. We will consider this email and the attached staff report as the City's comment on the file. We are still within the comment period, so if the City wants to provide any additional information or details, feel free to send them over before the hearing.

Thanks,

Jake Gabell, Director

Bonner County Planning Department

1500 Highway 2, Suite 208

Sandpoint, ID 83864

Phone: 208-265-1458

On Mon, May 12, 2025 at 4:36 PM Bill Dean <bdean@sandpointidaho.gov> wrote:

Hi Jake, thanks again for routing the Deerfield application to us for review/comment. Our City Council addressed this at last Wednesday's CC mtg and below is the excerpt from the DRAFT minutes which will go to CC next week for approval. Our staff report is [here](#):

Citing a conflict as the applicant to Bonner County for this development, Councilor Howarth recused himself from this matter and left the dais.

City Planner Bill Dean reviewed his staff report and packet materials with the Council and, along with Mayor Grimm and Mr. Jones, fielded questions. Council approved the comments from the City to Bonner County regarding the Deerfield Subdivision Application, as composed by City staff, with the following amendments:

- a. Include a suggestion for a right-of-way dedication on the corners of Lots 9 and 10 in Block 1 for future connectivity to the south and/or west.
- b. Include a suggestion that any access point included in this development onto the property owned by the City of Sandpoint to the east of this development be constructed from public right-of-way stubbed to the City property.

Motion made by Councilor Schreiber, Seconded by Councilor Duquette.

Voting Yea: Councilor Ruehle, Councilor Aispuro, Councilor Dick, Councilor Schreiber, Councilor Duquette

Abstaining: Councilor Howarth

The minutes will be posted next week after CC approval. Do you need anything else from us? We're happy to further discuss. We'd appreciate you sharing our City Council's requests, as described above and in the linked staff report with the Commissioners.

Thanks, Bill



City of Sandpoint Planning

Bill Dean | City Planner

Office | (208)265-1480

1123 Lake St. Sandpoint,

ID 83864

From: Jake Gabell <jake.gabell@bonnercountyid.gov>

Sent: Thursday, April 17, 2025 3:56 PM

To: Jason Welker <jwelker@sandpointidaho.gov>; Bill Dean <bdean@sandpointidaho.gov>

Cc: Alexander Feyen <alexander.feyen@bonnercountyid.gov>; Janna Brown <janna.berard@bonnercountyid.gov>; Jason Johnson <jason.johnson@bonnercountyid.gov>

Subject: Deerfield Subdivision - S0001-25

[Caution] This email originated from outside the City of Sandpoint organization. **Do not** click on links or open attachments unless you recognize the sender and know it's safe. When in doubt contact the [IT Department](#)

Good afternoon Gentlemen,

Here is the link to the Deerfield subdivision application and associated documents.

I understand that the applicant is pushing for this to be added to the May Zoning Commission agenda. To accomplish this, we would need something in writing stating that the City is waiving the 40-day notice requirement found in the current ACI agreement. In order to meet our other noticing requirements, we would have to send a public notice to the paper by Tuesday of next week.

I'm completely fine waiting to hold this hearing until June, as currently planned, but if the City is willing to waive its 40-day notice period, then we could hold the hearing sooner. Please note that per Bonner County Code, the Zoning Commission cannot make a decision on a preliminary plat. They make a recommendation to the BOCC, who will hold another hearing and make a decision on this file in the preliminary plat phase.

<https://www.bonnercountyid.gov/FileS0001-25>

Jake Gabell, Director

Bonner County Planning Department

[1500 Highway 2, Suite 208](#)

5/13/25, 12:37 PM

Bonner County Mail - Re: [EXT SENDER] RE: Deerfield Subdivision - S0001-25

[Sandpoint, ID 83864](#)

Phone: 208-265-1458