

# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0079562

Drilling Permit No. 911854  
Water right or injection well # \_\_\_\_\_

2. OWNER: \_\_\_\_\_  
Name Travis & Robyn Brookshire

Address \_\_\_\_\_  
City Descanso State CA Zip 91917

3. WELL LOCATION:  
Twp. 56 North  or South  Rge. 04 East  or West   
Sec. 33 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4

Gov't Lot \_\_\_\_\_ County Bonner  
Lat. 48° \_\_\_\_\_ 9.401'N (Deg. and Decimal minutes)  
Long. 116° \_\_\_\_\_ 49.950'W (Deg. and Decimal minutes)  
Address of Well Site 962 Moose Mountain Lane  
City Priest River

(Give at least name of road + distance to road or landmark)  
Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

5. TYPE OF WORK:  
 New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
Bentonite	0	38	1150lbs	Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+2	38	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4	20	100	.338	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) 38'

9. PERFORATIONS/SCREENS:  
Perforations  Y  N Method Saw

Manufactured screen  Y  N Type \_\_\_\_\_  
Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
49	100	1/8x6	42	4	PVC	.338

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

11. FLOWING ARTESIAN:  
Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:  
Depth first water encountered (ft) 41' Static water level (ft) 37'  
Water temp. (°F) Cold Bottom hole temp. (°F) Cold  
Describe access port Bolt on well cap

Well test: \_\_\_\_\_ Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
	8+	60	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	5	Granite med soft brown		X
10	5	11	Granite med brown		X
10	11	21	Granite med gray		X
10	21	38	Granite med hard gray		X
6	38	41	Granite med hard gray		X
6	41	43	Granite med fractured gray	X	
6	43	54	Granite med hard gray		X
6	54	55	Granite fractured gray	X	
6	55	71	Granite med hard gray		X
6	71	72	Granite fractured gray	X	
6	72	100	Granite med hard gray		X

**RECEIVED**

**SEP 23 2023**

**IDWR/NORTH**

Completed Depth (Measurable): 100'  
Date Started: Aug 18, 2023 Date Completed: Aug 18, 2023

14. DRILLER'S CERTIFICATION:  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Joyco Drilling Inc Co. No. 765  
\*Principal Driller [Signature] Date Sep 6, 2023  
\*Driller \_\_\_\_\_ Date \_\_\_\_\_  
\*Operator II \_\_\_\_\_ Date \_\_\_\_\_  
Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.